

ADDENDUM NO. 1

DATE OF ISSUANCE:	February 10, 2020
PROJECT:	Wayland High School Stadium Improvements 850 East Superior St. Wayland, MI 49348
OWNER:	Wayland Union Schools
ARCHITECT'S PROJECT NO.:	20-112.00
ORIGINAL BID ISSUE DATE:	February 6, 2020

SCOPE OF WORK

This Addendum includes changes to, or clarifications of, the original Bidding Documents and any previously issued addenda, and shall be included in the Bid. All of these Addendum items form a part of the Contract Documents. The Bidder shall acknowledge receipt of this Addendum in the appropriate space provided on the Bid Form. Failure to do so may result in disqualification of the Bid.

DOCUMENTS INCLUDED IN THIS ADDENDUM

This Addendum includes 2 pages of text and the following documents:

- Bidding Documents: None
- Contract Conditions: None
- Specification Sections: 26 5668
- Drawings: ES 101, E 401

CHANGES TO PREVIOUSLY ISSUED ADDENDA

None.

CHANGES TO BIDDING REQUIREMENTS

None.

CHANGES TO CONTRACT CONDITIONS

None.

CHANGES TO SPECIFICATIONS

ADD-1 Item No. S-1 - 26 5668 – Exterior Athletic Lighting

Refer to re-issued specification section 26 5668. The exterior athletic lighting specification has been revised.

CHANGES TO DRAWINGS

ADD-1 Item No. D-1 - Sheet ES 101 – ELECTRICAL SITE PLAN

Refer to Sheet ES 101 [re-issued].

Revise athletic lighting specification and Site Light Fixture Schedule as indicated. Add Electrical Sports Lighting Feeder Schedule with new feeder sizing for associated athletic lighting fixtures.

Revised raceway routing for lighting circuits and communications pathways to new athletic lighting poles as indicated. See also revised keyed note #1 and new keyed notes #11 and #12.

ADD-1 Item No. D-2 - Sheet E 401 – ELECTRICAL DETAILS

Refer to Sheet E 401 [re-issued].

Add stadium distribution switchboard “DP-ST” panelboard load schedule to show existing/new electrical loads.

END OF ADDENDUM.

SECTION 26 5668 – EXTERIOR ATHLETIC LIGHTING

PART 1 – GENERAL

1.1 SUMMARY

- A. Work covered by this section of the specifications shall conform to the contract documents, engineering plans as well as state and local codes.
- B. The purpose of these specifications is to define the lighting system performance and design standards for Wayland Union Schools High School using an LED Lighting source. The manufacturer / contractor shall supply lighting equipment to meet or exceed the standards set forth in these specifications.
- C. The sports lighting will be for the following venues:
 - 1. Football
- D. The primary goals of this sports lighting project are:
 - 1. Guaranteed Light Levels: Selection of appropriate light levels impact the safety of the players and the enjoyment of spectators. Therefore light levels are guaranteed to not drop below specified target values for a period of 25 years.
 - 2. Environmental Light Control: It is the primary goal of this project to minimize spill light to adjoining properties and glare to the players, spectators and neighbors.
 - 3. Cost of Ownership: In order to reduce the operating budget, the preferred lighting system shall be energy efficient and cost effective to operate. All maintenance costs shall be eliminated for the duration of the warranty.
 - 4. Control and Monitoring: To allow for optimized use of labor resources and avoid unneeded operation of the facility, customer requires a remote on/off control system for the lighting system. Fields should be proactively monitored to detect luminaire outages over a 25-year life cycle. All communication and monitoring costs for 25-year period shall be included in the bid.

1.2 LIGHTING PERFORMANCE

- A. Illumination Levels and Design Factors: Playing surfaces shall be lit to an average target illumination level and uniformity as specified in the chart below. Lighting calculations shall be developed and field measurements taken on the grid spacing with the minimum number of grid points specified below. Appropriate light loss factors shall be applied and submitted for the basis of design. Average illumination level shall be measured in accordance with the IESNA LM-5-04 (IESNA Guide for Photometric Measurements of Area and Sports Lighting Installations). Illumination levels shall not to drop below desired target values in accordance to IES RP-6-15, Page 2, Maintained Average Illuminance and shall be guaranteed for the full warranty period.

Area of Lighting	Average Target Illumination Levels	Maximum to Minimum Uniformity Ratio	Grid Points	Grid Spacing
Football	40 Footcandles	2.0:1.0	72	30' x 30'
Track	18 Footcandles		46	30' x 30'
Home Bleachers	8.5 Footcandles		147	10' x 10'
Visitor Bleachers	10 Footcandles		51	10' x 10'
Southwest Building	4 Footcandles		65	10' x 10'

- B. Color: The lighting system shall have a minimum color temperature of 5700K and a CRI of 75.
- C. Mounting Heights: To ensure proper aiming angles for reduced glare and to provide better playability, minimum mounting heights shall be as described below. Higher mounting heights may be required based on photometric report and ability to ensure the top of the field angle is a minimum of 10 degrees below horizontal.

# of Poles	Pole Designation	Pole Height
2	F1, F2	70'
2	F3, F4	80'

1.3 ENVIRONMENTAL LIGHT CONTROL

- A. Light Control Luminaires: All luminaires shall utilize spill light and glare control devices including, but not limited to, internal shields, louvers and external shields. No symmetrical beam patterns are accepted.
- B. Spill Scans: Spill scans must be submitted indicating the amount of horizontal and vertical footcandles along the specified lines. Light levels shall be taken at 30-foot intervals along the boundary line. Readings shall be taken with the meter orientation at both horizontal and aimed towards the most intense bank of lights. Illumination level shall be measured in accordance with the IESNA LM-5-04 after 1 hour warm up.
- C. The first page of a photometric report for all luminaire types proposed showing horizontal and vertical axial candle power shall be provided to demonstrate the capability of achieving the specified performance. Reports shall be certified by a qualified testing laboratory with a minimum of five years experience or by a manufacturer's laboratory with a current accreditation under the National Voluntary Laboratory Accreditation Program for Energy Efficient Lighting Products. A summary of the horizontal and vertical aiming angles for each luminaire shall be included with the photometric report.

1.4 COST OF OWNERSHIP

- A. Manufacturer shall submit a 25 year Cost of Ownership summary that includes energy consumption, anticipated maintenance costs, and control costs. All costs associated with faulty luminaire replacement – equipment rentals, removal and installation labor, and shipping – are to be included in the maintenance costs.

PART 2 – PRODUCT

2.1 SPORTS LIGHTING SYSTEM CONSTRUCTION

- A. Manufacturer: Basis of Design – Musco Lighting.
- B. Manufacturing Requirements: All components shall be designed and manufactured as a system. All luminaires, wire harnesses, drivers and other enclosures shall be factory assembled, aimed, wired and tested.
- C. Durability: All exposed components shall be constructed of corrosion resistant material and/or coated to help prevent corrosion. All exposed carbon steel shall be hot dip galvanized per ASTM A123. All exposed aluminum shall be powder coated with high performance polyester or anodized. All exterior reflective inserts shall be anodized, coated, and protected from direct environmental exposure to prevent reflective degradation or corrosion. All exposed hardware and fasteners shall be stainless steel of 18-8 grade or better, passivated and coated with aluminum-based thermosetting epoxy resin for protection against corrosion and stress corrosion cracking. Structural fasteners may be carbon steel and galvanized meeting ASTM A153 and ISO/EN 1461 (for hot dipped galvanizing), or ASTM B695 (for mechanical galvanizing). All wiring shall be enclosed within the cross-arms, pole, or electrical components enclosure.
- D. System Description: Lighting system shall consist of the following:
 1. Galvanized steel poles and cross-arm assembly.
 2. Non-approved pole technology:
 - a. Square static cast concrete poles will not be accepted.
 - b. Direct bury steel poles which utilize the extended portion of the steel shaft for their foundation will not be accepted due to potential for internal and external corrosive reaction to the soils and long term performance concerns.
 3. Lighting systems shall use concrete foundations. See Section 2.4 for details.
 - a. For a foundation using a pre-stressed concrete base embedded in concrete backfill the concrete shall be air-entrained and have a minimum compressive design strength at 28 days of 3,000 PSI. 3,000 PSI concrete specified for early pole erection, actual required minimum allowable concrete strength is 1,000 PSI. All piers and concrete backfill must bear on and against firm undisturbed soil.
 - b. For anchor bolt foundations or foundations using a pre-stressed concrete base in a suspended pier or re-inforced pier design pole erection may occur after 7 days. Or after a concrete sample from the same batch achieves a certain strength.
 4. Manufacturer will supply all drivers and supporting electrical equipment
 - a. Remote drivers and supporting electrical equipment shall be mounted approximately 10 feet above grade in aluminum enclosures. The enclosures shall be touch-safe and include drivers and fusing with indicator lights on fuses to notify when a fuse is to be replaced for each luminaire. Disconnect per circuit for each pole structure will be located in the enclosure.
 - b. Manufacturer shall provide surge protection at the pole equal to or greater than 40 kA for each line to ground (Common Mode) as recommended by IEEE C62.41.2_2002.
 5. Wire harness complete with an abrasion protection sleeve, strain relief and plug-in connections for fast, trouble-free installation.

6. All luminaires, visors, and cross-arm assemblies shall withstand 150 mph winds and maintain luminaire aiming alignment.
 7. Control cabinet to provide remote on-off control and monitoring features of the lighting system. See Section 2.3 for further details.
 8. Contactor cabinet to provide on-off control.
 9. Manufacturer shall provide lightning grounding as defined by NFPA 780 and be UL Listed per UL 96 and UL 96A.
 - a. Integrated grounding via concrete encased electrode grounding system.
 - b. If grounding is not integrated into the structure, the manufacturer shall supply grounding electrodes, copper down conductors, and exothermic weld kits. Electrodes and conductors shall be sized as required by NFPA 780. The grounding electrode shall be minimum size of 5/8 inch diameter and 8 feet long, with a minimum of 10 feet embedment. Grounding electrode shall be connected to the structure by a grounding electrode conductor with a minimum size of 2 AWG for poles with 75 feet mounting height or less, and 2/0 AWG for poles with more than 75 feet mounting height.
- D. Safety: All system components shall be UL listed for the appropriate application.

2.2 ELECTRICAL

- A. Electric Power Requirements for the Sports Lighting Equipment:
 1. Electric power: See Plans for Voltage and Phase
 2. Maximum total voltage drop: Voltage drop to the disconnect switch located on the poles shall not exceed three (3) percent of the rated voltage.
- B. Energy Consumption: The kW consumption for the field lighting system shall be 53.75.

2.3 CONTROL

- A. Instant On/Off Capabilities: System shall provide for instant on/off of luminaires.
- B. Lighting contactor cabinet(s) constructed of NEMA Type 4 aluminum, designed for easy installation with contactors, labeled to match field diagrams and electrical design. Manual off-on-auto selector switches shall be provided.
- C. Dimming: System shall provide for 3-stage dimming (high-medium-low). Dimming with be set via scheduling options (Website, app, phone, fax, email)
- D. Remote Lighting Control System: System shall allow owner and users with a security code to schedule on/off system operation via a web site, phone, fax or email up to ten years in advance. Manufacturer shall provide and maintain a two-way TCP/IP communication link. Trained staff shall be available 24/7 to provide scheduling support and assist with reporting needs.

The owner may assign various security levels to schedulers by function and/or fields. This function must be flexible to allow a range of privileges such as full scheduling capabilities for all fields to only

having permission to execute "early off" commands by phone. Scheduling tool shall be capable of setting curfew limits.

Controller shall accept and store 7-day schedules, be protected against memory loss during power outages, and shall reboot once power is regained and execute any commands that would have occurred during outage.

- E. Remote Monitoring System: System shall monitor lighting performance and notify manufacturer if individual luminaire outage is detected so that appropriate maintenance can be scheduled. The controller shall determine switch position (manual or auto) and contactor status (open or closed).
- F. Management Tools: Manufacturer shall provide a web-based database and dashboard tool of actual field usage and provide reports by facility and user group. Dashboard shall also show current status of luminaire outages, control operation and service. Mobile application will be provided suitable for IOS, Android and Blackberry devices.

Hours of Usage: Manufacturer shall provide a means of tracking actual hours of usage for the field lighting system that is readily accessible to the owner.
 - 1. Cumulative hours: shall be tracked to show the total hours used by the facility
- G. Communication Costs: Manufacturer shall include communication costs for operating the control and monitoring system for a period of 25 years.
- H. Communication with luminaire drivers: Control system shall interface with drivers in electrical components enclosures by means of powerline communication.

2.4 STRUCTURAL PARAMETERS

- A. Wind Loads: Wind loads shall be based on the 2015 International Building Code. Wind loads to be calculated using ASCE 7-10, an ultimate design wind speed of 115mph and exposure category C.
- B. Pole Structural Design: The stress analysis and safety factor of the poles shall conform to 2013 AASHTO Standard Specification for Structural Supports for Highway Signs, Luminaires, and Traffic Signals (LTS-6).
- C. Foundation Design: The foundation design shall be based on soil parameters as outlined in the geotechnical report. OR If no geotechnical report is available, the foundation design shall be based on soils that meet or exceed those of a Class 5 material as defined by 2015 IBC Table 1806.2.

PART 3 – EXECUTION

3.1 SOIL QUALITY CONTROL

- A. It shall be the Contractor's responsibility to notify the Owner if soil conditions exist other than those on which the foundation design is based, or if the soil cannot be readily excavated. Contractor may issue a change order request / estimate for the Owner's approval / payment for additional costs associated with:
 - 1. Providing engineered foundation embedment design by a registered engineer in the State of Michigan for soils other than specified soil conditions;
 - 2. Additional materials required to achieve alternate foundation;

3. Excavation and removal of materials other than normal soils, such as rock, caliche, etc.

3.2 DELIVERY TIMING

- A. Delivery Timing Equipment On-Site: The equipment must be on-site 6-8 weeks from receipt of approved submittals and receipt of complete order information.

3.3 FIELD QUALITY CONTROL

- A. Illumination Measurements: Upon substantial completion of the project and in the presence of the Contractor, Project Engineer, Owner's Representative, and Manufacturer's Representative, illumination measurements shall be taken and verified. The illumination measurements shall be conducted in accordance with IESNA LM-5-04.
- B. Field Light Level Accountability
 1. Light levels are guaranteed not to fall below the target maintained light levels for the entire warranty period of 25 years. These levels will be specifically stated as "guaranteed" on the illumination summary provided by the manufacturer.
 2. The contractor/manufacturer shall be responsible for conducting initial light level testing and an additional inspection of the system, in the presence of the owner, one year from the date of commissioning of the lighting.
 3. The contractor/manufacturer will be held responsible for any and all changes needed to bring these fields back to compliance for light levels and uniformities. Contractor/Manufacturer will be held responsible for any damage to the fields during these repairs.
- C. Correcting Non-Conformance: If, in the opinion of the Owner or his appointed Representative, the actual performance levels including footcandles and uniformity ratios are not in conformance with the requirements of the performance specifications and submitted information, the Manufacturer shall be required to make adjustments to meet specifications and satisfy Owner.

3.4 WARRANTY AND GUARANTEE

- A. 25-Year Warranty: Each manufacturer shall supply a signed warranty covering the entire system for 25 years from the date of shipment. Warranty shall guarantee specified light levels. Manufacturer shall maintain specifically-funded financial reserves to assure fulfillment of the warranty for the full term. Warranty does not cover weather conditions events such as lightning or hail damage, improper installation, vandalism or abuse, unauthorized repairs or alterations, or product made by other manufacturers.
- B. Maintenance: Manufacturer shall monitor the performance of the lighting system, including on/off status, hours of usage and luminaire outage for 25 years from the date of equipment shipment. Parts and labor shall be covered such that individual luminaire outages will be repaired when the usage of any field is materially impacted. Manufacturer is responsible for removal and replacement of failed luminaires, including all parts, labor, shipping, and equipment rental associated with maintenance. Owner agrees to check fuses in the event of a luminaire outage.

PART 4 – DESIGN APPROVAL

4.1 PRE-BID SUBMITTAL REQUIREMENTS FOR ALTERNATE MANUFACTURES

- A. Design Approval: The owner / engineer will review pre-bid submittals per section 4.0.B from all the manufacturers to ensure compliance to the specification 10 days prior to bid. If the design meets the design requirements of the specifications, an addendum will be issued to the manufacturer indicating approval for the specific design submitted.
- B. Approved Product: Musco's Light-Structure System™ with TLC for LED™ is the approved product. All substitutions must provide a complete submittal package for approval as outlined in Submittal Information at the end of this section at least 10 days prior to bid. Special manufacturing to meet the standards of this specification may be required. An addendum will be issued prior to bid listing any other approved lighting manufacturers and designs.
- C. All listed manufacturers not pre-approved shall submit the information at the end of this section at least 10 days prior to bid. An addendum will be issued prior to bid; listing approved lighting manufacturers and the design method to be used.
- D. Bidders are required to bid only products that have been approved by this specification or addendum by the owner or owner's representative. Bids received that do not utilize an approved system/design, will be rejected.

REQUIRED SUBMITTAL INFORMATION FOR ALL MANUFACTURERS (NOT PRE-APPROVED) 10 DAYS PRIOR TO BID

A. *All items listed below are mandatory, shall comply with the specification and be submitted according to pre-bid submittal requirements. Complete the Yes/No column to indicate compliance (Y) or noncompliance (N) for each item. **Submit checklist below with submittal.***

B.

Yes/No	Tab	Item	Description
	A	Letter/ Checklist	Listing of all information being submitted must be included on the table of contents. List the name of the manufacturer's local representative and his/her phone number. Signed submittal checklist to be included.
	B	Equipment Lay-out	Drawing(s) showing field layouts with pole locations
	C	On Field Lighting Design	Lighting design drawing(s) showing: <ol style="list-style-type: none"> Field Name, date, file number, prepared by Outline of field(s) being lighted, as well as pole locations referenced to the center of the field (x & y), Illuminance levels at grid spacing specified Pole height, number of fixtures per pole, horizontal and vertical aiming angles, as well as luminaire information including wattage, lumens and optics Height of light test meter above field surface. Summary table showing the number and spacing of grid points; average, minimum and maximum illuminance levels in foot candles (fc); uniformity including maximum to minimum ratio, coefficient of variance (CV), coefficient of utilization (CU) uniformity gradient; number of luminaires, total kilowatts, average tilt factor; light loss factor.
	D	Off Field Lighting Design	Lighting design drawing showing initial spill light levels along the boundary line (defined on bid drawings) in footcandles. Lighting design showing glare along the boundary line in candela. Light levels shall be taken at 30-foot intervals along the boundary line. Readings shall be taken with the meter orientation at both horizontal and aimed towards the most intense bank of lights.
	E	Photometric Report	Provide first page of photometric report for all luminaire types being proposed showing candela tabulations as defined by IESNA Publication LM-35-02. Photometric data shall be certified by laboratory with current National Voluntary Laboratory Accreditation Program or an independent testing facility with over 5 years experience.
	F	Performance Guarantee	Provide performance guarantee including a written commitment to undertake all corrections required to meet the performance requirements noted in these specifications at no expense to the owner. Light levels must be guaranteed to not fall below target levels for warranty period.
	G	Structural Calculations	Pole structural calculations and foundation design showing foundation shape, depth backfill requirements, rebar and anchor bolts (if required). Pole base reaction forces shall be shown on the foundation drawing along with soil bearing pressures. Design must be stamped by a structural engineer in the state of MI, if required by owner. (May be supplied upon award).
	H	Control & Monitoring System	Manufacturer of the control and monitoring system shall provide written definition and schematics for automated control system. They will also provide ten (10) references of customers currently using proposed system in the state of MI.
	I	Electrical Distribution Plans	Manufacturer bidding an alternate product must include a revised electrical distribution plan including changes to service entrance, panels and wire sizing, signed by a licensed Electrical Engineer in the state of MI.
	J	Warranty	Provide written warranty information including all terms and conditions. Provide ten (10) references of customers currently under specified warranty in the state of MI.
	K	Project References	Manufacturer to provide a list of ten (10) projects where the technology and specific fixture proposed for this project has been installed in the state of MI. Reference list will include project name, project city, installation date, and if requested, contact name and contact phone number.
	L	Product Information	Complete bill of material and current brochures/cut sheets for all product being provided.
	M	Delivery	Manufacturer shall supply an expected delivery timeframe from receipt of approved submittals and complete order information.

	N	Non-Compliance	Manufacturer shall list all items that do not comply with the specifications. If in full compliance, tab may be omitted.
	O	Cost of Ownership	Document cost of ownership as defined in the specification. Identify energy costs for operating the luminaires. Maintenance cost for the system must be included. All costs should be based on 25 Years

The information supplied herein shall be used for the purpose of complying with the specifications for Wayland High School Football. By signing below I agree that all requirements of the specifications have been met and that the manufacturer will be responsible for any future costs incurred to bring their equipment into compliance for all items not meeting specifications and not listed in the Non-Compliance section.

Manufacturer: _____

Signature: _____

Contact Name: _____

Date: ____ / ____ / ____

Contractor: _____

Signature: _____

END OF SECTION 26 5668

ELECTRICAL KEYED NOTES

- NEW CONDUIT SHALL BE INSTALLED FROM THE PRESS BOX TO THE NEW PERFORMANCE LIGHTING. PROVIDE NEW FEEDS TO SPOKES IN PANEL DP-ST. REUSE EXISTING RACEWAY WHERE POSSIBLE.
- PROVIDE SPOKESFIELD SPECIALTIES #BING1830 IN-GRADE JUNCTION BOXES TO BE INSTALLED UNDER THE PRESS BOX. PROVIDE CRUSHED STONE DRAINAGE UNDER IN-GROUND JUNCTION BOX.
- ROUTE (2) 2" CONDUIT FROM DATA RACK IN TEAM BUILDING ELECTRICAL ROOM TO NEW 12"x24" HAND HOLE BEHIND SPOKES IN PRESS BOX. PROVIDE COMMUNICATIONS CABLING. PROVIDE PULL STRING IN CONDUIT.
- ROUTE (1) 2" CONDUIT FROM NEW 12"x24" HAND HOLE BEHIND SOUTHEAST SPOKES LIGHTING POLE TO NEW 12"x24" HAND HOLE BEHIND SPOKES IN PRESS BOX. PROVIDE COMMUNICATIONS CABLING. PROVIDE PULL STRING IN CONDUIT.
- ROUTE (1) 1" CONDUIT FOR POWER AND (2) 2" CONDUIT FOR COMMUNICATIONS CABLING TO NEW IN-GRADE JUNCTION BOX FROM ELECTRICAL ROOM IN TEAM BUILDING. PROVIDE PULL STRING IN CONDUIT.
- ROUTE (2) 2" CONDUIT FROM DATA RACK IN PRESS BOX BUILDING TO NEW IN-GRADE JUNCTION BOXES FOR COMMUNICATIONS CABLING. PROVIDE PULL STRING IN CONDUIT.
- ROUTE (1) 2" CONDUIT FROM DATA RACK IN PRESS BOX BUILDING TO NEW 12"x24" HAND HOLE ADJACENT TO SPOKES LIGHTING POLE FOR FUTURE COMMUNICATIONS CABLING. PROVIDE PULL STRING IN CONDUIT.
- PROVIDE NEW DIGITAL PLAY CLOCK AND CONNECT TO EXISTING FINISHED GRADE TO EXTERIOR WALL OF BUILDING. ROUTE (1) 1" CONDUIT BACK TO MAIN ELECTRICAL ROOM IN CONGRESSIONS BUILDING TO NEW ELECTRICAL ROOM TO CONTRACTOR CONTROLLING AREA LIGHTING ON LIGHTING POLES
- ROUTE (1) 1" CONDUIT FROM TB-DF IN MECHANICAL T102 ABOVE CEILING(S) TO NEW DIGITAL PLAY CLOCK IN TEAM ROOM.
- MOUNT WEATHER PROOF RATED OCCUPANCY SENSOR AT 8' ABOVE FINISHED GRADE TO EXTERIOR WALL OF BUILDING. ROUTE (1) 1" CONDUIT BACK TO MAIN ELECTRICAL ROOM IN CONGRESSIONS BUILDING TO NEW ELECTRICAL ROOM TO CONTRACTOR CONTROLLING AREA LIGHTING ON LIGHTING POLES
- INTERCEPT EXISTING LIGHTING CIRCUIT AT HAND HOLE AND EXTEND TO NEW NORTHWEST SPOKES LIGHTING POLE LOCATION AS INDICATED.
- INTERCEPT EXISTING LIGHTING CIRCUIT AT HAND HOLE AND EXTEND TO NEW NORTHEAST SPOKES LIGHTING POLE LOCATION AS INDICATED.

APPENDIX #1
 ISSUED FOR
 DATE
 02-10-2020

OWNER
 WAYLAND UNION SCHOOLS
 WAYLAND, MICHIGAN
 PROJECT TITLE
 WAYLAND HIGH SCHOOL STADIUM
 IMPROVEMENTS

SHEET TITLE
 ELECTRICAL SITE PLAN
 SHEET NUMBER
 ES 101
 DATE
 FEBRUARY 6, 2020

480 V.
 LIGHTING - SPOKES LIGHTING POLE F1
 LIGHTING - SPOKES LIGHTING POLE F2
 LIGHTING - SPOKES LIGHTING POLE F3
 LIGHTING - SPOKES LIGHTING POLE F4

1 REUSE EXISTING 30A/3P CIRCUIT BREAKER MADE AVAILABLE THROUGH DEMOLITION OF EXISTING ATHLETIC FIELD LIGHTING. REUSE EXISTING CONDUIT AND RACEWAY IN ROUTING NEW FEEDER TO NEW ATHLETIC LIGHTING.

ELECTRICAL SPORTS LIGHTING FEEDER SCHEDULE

DESCRIPTION	FED FROM	CURRENT (FLA)	BREAKER / POLES	# OF SETS	WIRE	GROUND	EMT	FEED VOLT DROP %	NOTES
16 A	DP-ST	30 A / 3	1 SET	3 #6	#6 GND	3/4"	2.73%	1	
16 A	DP-ST	30 A / 3	1 SET	3 #6	#6 GND	3/4"	1.44%	1	
16 A	DP-ST	30 A / 3	1 SET	3 #6	#6 GND	3/4"	2.61%	1	
17 A	DP-ST	30 A / 3	1 SET	3 #6	#6 GND	3/4"	2.01%	1	

SITE LIGHT FIXTURE SCHEDULE

TYPE	DESCRIPTION	MOUNTING	WATTS	MANUFACTURER	NOTES
F1	LED PERFORMANCE FIELD LIGHT	80' POLE	13170 VA	MUSCO: #TLC-LED-600 @ 60' MOUNTING HEIGHT MUSCO: #TLC-LED-1500 @ 70' MOUNTING HEIGHT	1, 2
F2	LED PERFORMANCE FIELD LIGHT	80' POLE	13170 VA	MUSCO: #TLC-LED-600 @ 60' MOUNTING HEIGHT MUSCO: #TLC-LED-1500 @ 70' MOUNTING HEIGHT	1, 2
F3	LED PERFORMANCE FIELD LIGHT	80' POLE	12990 VA	MUSCO: #TLC-LED-575 @ 15.5' MOUNTING HEIGHT MUSCO: #TLC-LED-1500 @ 70' MOUNTING HEIGHT	1, 2
F4	LED PERFORMANCE FIELD LIGHT	80' POLE	14420 VA	MUSCO: #TLC-LED-400 @ 60' MOUNTING HEIGHT MUSCO: #TLC-LED-575 @ 15.5' MOUNTING HEIGHT MUSCO: #TLC-LED-1500 @ 70' MOUNTING HEIGHT	1, 2

ALL THE FIXTURES TO BE INSTALLED SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTALLATION INSTRUCTIONS FOR SPECIFIC MOUNTING DETAILS.
 REFER TO SHOP DRAWINGS AND MANUFACTURERS INSTALLATION INSTRUCTIONS FOR SPECIFIC MOUNTING DETAILS.
 REFER TO BUILDING ELEVATIONS FOR FIXTURE PLACEMENT, CENTER OVER DOORS, ALIGN SIMILAR FIXTURES.

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"

3
 ENLARGED TEAM ROOM ELECTRICAL PLAN
 1/8" = 1'-0"



