



BID ADDENDUM #2

BID 15-013

PROJECT / BID NUMBER: 15-013

PROJECT NAME: FY16 Water Treatment Chemicals

ADDENDUM NO: 2

ISSUE DATE: 5/6/15

TO ALL BIDDERS: This addendum is issued for the purposes of modifying the original Bid, through addition, deletion, clarification or correction as outlined herein. The information provided in this addendum supersedes any information previously provided in the referenced document(s). This addendum and the information contained herein shall be used in the preparation of any bid submitted by the Bidder and shall become an integral part of the contract documents for any contract awarded for the project specified. Please inform all concerned that the Request is modified by this Addendum.

ADD/CHANGE/DELETE:

CHANGE/REPLACE: line 48 on Pricing Grid (Special Considerations for Plant 1):

1. **REPLACE the 3rd bullet for Phosphate Additive with:**

- Supplier must provide mild steel coupon study quarterly for corrosion control program. Two (2) coupon study racks with three (3) mid steel coupons per rack are to be supplied upon award (PRIOR to the first order) and the study results along with replacement coupons are to be provided quarterly.

NOTE:

Since we are using a different submission method for this bid. **EITHER** upload the acknowledgement page to show that they have been received/acknowledged **OR** specifically note in your email that all xx of the acknowledgements have been read and considered.

END