

Addendum #11

Walnut Plaza and Ed Johnson Memorial

CONTRACT NO. R-19-007

Bid schedule per Addendum #10

Pre-Bid Meeting September 17th at 10:00 am

Bid Opening November 5th at 2:00 pm

Question received via email:

1. Item # 76 on the bid form is asking for a lump sum for relocated irrigation power. This scope is not shown or identified on the drawings. Please provide clarification on the extent of scope requested to be performed.
 - a. This item is part of the Ed Johnson Memorial scope of work. The existing irrigation controller is mounted to a post in the center of the Memorial's LOD. The controller shall be relocated to the east, under the overhang of the bridge. Final location to be field coordinated with Ross Fowler and the Artist. Controller will be post mounted. Contractor will provide all work necessary to relocate the controller and ensure that service to the Plaza meets the performance specifications laid out in Section 328400 of the Project Specifications.

In addition to relocating the controller, the Contractor shall provide means for the Artist's landscape contractor to access the mainline, a 2 wire connection, and room on the controller for 5 additional irrigation zones.