

**ADDENDUM NO. 1**

**Issue Date: July 5, 2024**

This Addendum shall become and form a part of the RFB for:

**RFB-2024-07**

**HOLLY SPRINGS TOWN CENTER PARKING DECK FIRE SUPPRESSION**

**NOTE: PLEASE REVIEW CAREFULLY! THERE MAY BE CHANGES TO THE INFORMATION TO BE PROVIDED. FAILURE TO ADHERE TO ANY CHANGES ADDRESSED IN THIS ADDENDUM MAY RESULT IN DISQUALIFICATION.**

In the event of a conflict between previously released information and the information contained herein, the latter shall control.

Note: A signed acknowledgment of this addendum (this page) **MUST** be attached to your submittal.

Firm Name: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Typed Name and Title: \_\_\_\_\_

City of Holly Springs  
3237 Holly Springs Parkway  
Holly Springs, GA, 30115

This addendum, including all questions and answers, shall become and form a part of the original RFB package and shall be taken into account when preparing your proposal.

**The purpose of this addendum is to provide the answers to the written questions received during the question and answer period of the RFQ as follows:**

Written Questions and Answers:

1. Are there any manual pull stations or horn strobes on any floors, or any other form of notification or initiating devices?

Weatherproof pull stations are required on every level in the stairwells of the parking deck.