

**PURCHASING
AND MATERIALS
MANAGEMENT**

**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

**Addendum #01
April 9, 2024
IFB 24-B0040
Annual Resurfacing**

The purpose of this Addendum #01 to IFB 24-B0040 for Annual Resurfacing, dated April 9, 2024, is to provide answers to the following submitted questions, list the key points of discussion from the pre-bid meeting, and provide the pre-bid sign-in sheet:

1. For 31st Avenue North parking lot, 47th Avenue North parking lot, 71st Avenue North roadway parking spaces and parking lot, 8th Avenue South parking lot, 27th Avenue South parking lot, does the City want thermo or paint?

All paved areas will have temporary paint applied for all items immediately after paving. Thermoplastic markings will be applied fourteen (14) days after the initial application of temporary paint.

2. There is a parking area between Flagg Street and North Ocean Boulevard; will this be repaved, and if so, will the City want thermo or paint for the spaces?

The parking area between Flagg Street and North Ocean Boulevard will be repaved. The City requires that temporary paint be applied immediately after paving. Thermoplastic markings will be applied fourteen (14) days after the initial application of temporary paint.

3. Will the Contractor be supplying new parking bumpers?

Parking bumpers will be reused unless they are damaged beyond repair. Any parking bumpers that are beyond repair will be supplied by the City.

4. There is a traffic signal at the intersection of Kings Highway and 48th Avenue North. Loop cuts are not visible. Are there any loops that need to be installed there?

There is one (1) figure 8 loop at 48th Avenue North and Kings Highway.

5. If the City wants thermo parking spaces, do they want all striping in the parking lots in thermo, such as handicap symbols, hashing, “No Parking,” etc.?

All work areas will be temporarily painted immediately after completion. Thermoplastic will be applied fourteen (14) days after completion.

6. In the maps provided for this project, it includes 71st Avenue North from North Ocean Boulevard to North Kings Highway – however, 71st Avenue North is not mentioned anywhere on pages 04113-3 through -5. Please confirm if 71st Avenue North is part of the project or has been excluded.

71st Avenue North has been excluded from this project.

7. On several of the street ends, there are existing palm/palmetto trees with asphalt around them. Is it the intent of the City to retain these trees? If so, how would the City like for asphalt to be installed once we’ve removed asphalt around them? Finally, if the City does not wish to retain them – will a pay item be included to remove and dispose of the trees?

The City intends to retain all trees in the project work areas. The Contractor shall remove all old asphalt and reinstall new asphalt pavement around the base of the trees.

8. There is an asphalt curb on 3rd Avenue North – please confirm that this contract does not include any hand work to resurface this asphalt curb or backfill shoulder behind it.

This Contract does not require any work to the asphalt berm.

9. On the 8th Avenue South street end – I’m going to assume that the newer asphalt for the perpendicular parking is the hotel owner’s responsibility. Can you confirm? Also after full depth repairs, is it the intent of the City to pave new surface flush to the top of the sidewalk along the north side of the street parking? It’s currently inconsistent and could be considered a trip hazard. Or will we be milling along the face of the sidewalk?

The newer asphalt for the perpendicular parking is the hotel owner’s responsibility. The Contractor shall not mill the newer asphalt and must stop at the joint. The Contractor shall mill and pave the street end.

10. Should the replacement of all wheel stops be included in the Thermoplastic LS of each road?

Wheel stops will be retained and reinstalled by the Contractor. If the wheel stops are broken, the City will provide new stops.

Below are the key points of discussion from the pre-bid meeting:

- **The timeline for this project has been changed.** The completion date is November 1, 2024 for all items. Please disregard the July 1st, 2024 date as well as the 365-day completion time.
- The City reserves the right to add or remove roads to/from this Contract. The completion time will be considered if any roads are added.
- Liquidated damages are \$500.00 per day.
- The prime Contractor is responsible for 70% of the work of this Contract.
- The City acknowledges material lead time issues and will work with the awarded Contractor in relation to the Notice to Proceed and completion time.

All bids must be submitted to the Procurement Office at 3231 Mr. Joe White Avenue, Myrtle Beach, SC 29577 prior to 2:00p.m. (local time) on Tuesday, April 16, 2024.

Thank you,

City of Myrtle Beach
Brandon Hancock
Purchasing Office/Buyer
Email: bhancock@cityofmyrtlebeach.com



City of Myrtle Beach
SOUTH CAROLINA

PURCHASING AND
MATERIALS MANAGEMENT

(843) 918-2170
FAX: (843) 918-2182

MANDATORY PRE-BID: Tuesday, March 26, 2024 @ 10:00a.m.

BID: IFB 24-B0040 – Annual Resurfacing

BID OPENING: Tuesday, April 16, 2024 @ 2:00p.m.

Please sign in:

1) King Asphalt, Inc Steve Starbuck
 Company Name Representative Name (Print)
843-877-9939 [Signature]
 Phone Signature
sstarbuck@kingasphaltinc.com
 Email Address

2) Palmetta Corp Ryan Roscoe
 Company Name Representative Name (Print)
843-907-0218 [Signature]
 Phone Signature
roscoe@palmettacorp.com
 Email Address

3) _____
 Company Name Representative Name (Print)

 Phone Signature

 Email Address

MAILING ADDRESS: CITY OF MYRTLE BEACH • P.O. BOX 2468 • MYRTLE BEACH, SOUTH CAROLINA 29578-2468
OFFICE ADDRESS: CITY OF MYRTLE BEACH • 3231 -10th AVENUE NORTH EXT. • MYRTLE BEACH, SOUTH CAROLINA 29577