



**PURCHASING
AND MATERIALS
MANAGEMENT**

**City of Myrtle Beach
SOUTH CAROLINA**

**(843) 918-2170
FAX: (843) 918-2182
www.cityofmyrtlebeach.com**

**Addendum #02
November 22, 2022**

**IFB 23-B0028
Brick and Concrete Repairs at City Hall**

The purpose of this Addendum #02 to IFB 23-B0028 for Brick and Concrete Repairs at City Hall, dated November 4, 2022, and previously amended on November 14, 2022, is to answer the following questions:

1. Will saw cutting of existing brick to remove trip hazards be permissible if, in fact, it is the brick and not adjacent concrete or other surfaces causing the hazard?

No, saw cutting of existing bricks is not permissible. All bricks are to remain whole with all underlying obstructions removed to make a flat surface with no trip hazards.

2. Can you please clarify the unit definition of "JA" on the bid form?

JA is the American National Standards Institute (ANSI) abbreviation for "job."

3. Is there a quantity reference available for the required scopes of this project (ex: linear feet, square feet, number of hazards, etc?)

The entire surface area is approximately 3,000 square feet of brickwork and approximately 370 square feet of concrete to be removed/replaced. Contractors are responsible for their own measurements and should not rely solely on City estimates.

Bids will be received from pre-qualified contractors who attended the mandatory site visit. Sealed bids are due no later than Wednesday, November 30, 2022 at 2:00PM (local time.) No electronic submissions will be accepted. The City is not responsible for late or misdirected mail.

Ann Sowers
Purchasing Manager
Email: asowers@cityofmyrtlebeach.com