



Terry McKee, IT & Procurement Director

901 N. Broadway • Knoxville, TN 37917-6699  
 865.403.1133 • Fax 865.594.8858  
 purchasinginfo@kcdc.org  
 www.kcdc.org

**Addendum**

<b>Solicitation Name</b>	Elevator Maintenance Services Q2107	<b>Addendum Number</b>	1	<b>Date</b>	11/13/2020
--------------------------	-------------------------------------	------------------------	---	-------------	------------

This addendum answers questions raised about this solicitation. Questions are generally verbatim as received. To aid in readability, the questions are in black, the answers are in **bolded blue** and follow immediately below the question.

Q1	Does KCDC want monthly service for the freight elevator in the Procurement building? <b>KCDC only wants the minimum required by the State of Tennessee. It is our understanding that this is a once per year Safety Test. This elevator is very, very seldom used.</b>
Q2	Are the elevator controllers in the Main Office Building and the Verandas non-proprietary? <b>While those controllers are from National Elevator, KCDC is informed that any company can service those elevators. Suppliers may indicate a cost to update/replace those controllers if so desired.</b>

