

**ARLINGTON COUNTY, VIRGINIA
OFFICE OF THE PURCHASING AGENT**

INVITATION TO BID NO. 21-DES-ITB-626

ADDENDUM NO. 2

Arlington County Invitation to Bid No. 21-DES-ITB-626 for the construction of a retaining wall at 2900 S Eads is amended as follows:

- A. Attachment F – Geotechnical Engineering Report is hereby **added** with this addendum.
- B. The following are clarification to questions received.
 - 1. Will a door schedule with specifications for doors, frames, and hardware (shown on sheet S101) be provided? 2. Will the Arlington County security vendor (ADT) completely take care of supplying, and installing the complete access control system shown on details 7 and 8 on sheet S501? This also would include all conduit, wiring, and permitting. Will this work be under a separate contract directly with Arlington County?
Answer: **No schedule will be provided. Please see Sheet S-101, Note 2, for door and frame requirements. ADT will supply the hardware, harness, and conduit and wiring from their panel to the doors. However the contractor is to provide thee pathways at the door within the wall or new openings to the junction box above the door. So at the door the infrastructure is apart of the wall and door construction then ADT supplies the equipment and wiring to the junction box, then from the junction box to ADT panel will be solely provided by ADT.**
 - 2. Is there a geotech report available for this project?
Answer **See Attachment F – Geotechnical Engineering Report**
 - 3. Bid specification section 1.11 states that activities such as welding and demolition are to be performed off hours or at night. Please confirm if these activities can be performed 7AM - 5PM. Answer: **Confirmed, to be performed during normal working hours 7am to 7pm.**
 - 4. The drawings do not show the length of the tiebacks but reference a tieback schedule which is not included. Please provide the tieback schedule.
Answer: **The bonded and free lengths are shown in section 2 and 3 on sheet B-301. The tieback schedule on B-601 indicates elevation and batter angle.**

The balance of the solicitation remains unchanged.

Arlington County, Virginia

Sy Gezachew
Procurement Officer

RETURN THIS PAGE, FULLY COMPLETED AND SIGNED, WITH YOUR BID:

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM NUMBER 2.

FIRM NAME: _____

**AUTHORIZED
SIGNATURE:** _____ **DATE:** _____