



Terry McKee, IT & Procurement Director

901 N. Broadway • Knoxville, TN 37917-6699  
 865.403.1133 • Fax 865.594.8858  
 purchasinginfo@kcdc.org  
 www.kcdc.org

**Addendum**

<b>Solicitation Name</b>	HVAC Services at Eastport C21002	<b>Addendum Number</b>	3	<b>Date</b>	08/13/2020
--------------------------	----------------------------------	------------------------	---	-------------	------------

This addendum answers questions raised about this solicitation. Questions are generally verbatim as received. To aid in readability, the questions are in black, the answers are in **bolded blue** and the answers follow immediately below.

Q1	The solicitation requests for the replacement of (28) total indoor evaporators, but there are a total of (31) units currently installed. Are you all planning on only replacing some of the units?
	<b>Indeed there are 31 units to be replaced.</b>
Q2	The solicitation requests Trane/Mitsubishi ducted mini-splits be used as the replacement units. Are you all opposed to using Daikin VRV's instead? We are still awaiting a response from our Trane/Mitsubishi reps and can expedite this process if you were to make this change.
	<b>That is acceptable.</b>
Q3	Is the goal to move the outdoor condensers from their existing location behind the building to the roof or mounted on the wall? This will add considerable cost vs replacing them in their existing location.
	<b>Move them behind the building to the roof or mount them on the wall.</b>
Q4	Will extend the due date?
	<b>Yes. The revised due date is August 18, 2020 at 11:00 a.m.</b>

