



St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: March 3, 2023

TO: Prospective Respondents

FROM: Amy Lucey, Procurement Specialist

SUBJECT: Addendum #1 to Invitation for Bid, # 38498, Geosynthetic Slope Stabilization – Welland Road, Lake Apopka.

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1: Could you provide a contact for the material supplier used in the past?

A1: Casey Cittadino: email: casey@soxerosion.com; cell: 631-478-8567

Q2: Could you provide the actual cross sections of the area to be worked?

A2: Here are the water depths starting at the south end of the project and heading north approximately every 500-feet, measuring approximately 2', 4' & 7' off the bank at the waterline. See cross-section for additional information.

- 3.4', 5', 7'
- 3.6', 3.9, 7'
- 3.2', 4.5', 7'
- 3.2', 4.1', 4.8'
- 3.2', 4', 4.6'

Q3: Is a laydown area available?

A3: Yes, the contractor may use the parking lot adjacent to Welland Road (west of Bailey Bridge) as a laydown area.

Q4: Could you provide a couple of pictures of the installation of the pilot project?

A4: Pictures are attached.

Q5: Is dewatering required?

A5: The selected product can be installed in the "wet". No dewatering is required.

Attachments:

Pilot Project pictures

Pre-bid sign in sheet 3-2-23 – Separate Cover

NOTE: The Bid Due Date remains 2:00 p.m., **Thursday March 9, 2023**

Please acknowledge receipt of this Addendum on the Bid FORM provided in the proposal package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.

SJRWMD GEOSYNTHETIC SLOPE STABILIZATION PILOT PROJECT





SJRWMD GEOSYNTHETIC SLOPE STABILIZATION PILOT PROJECT

