



Terry McKee, Procurement Director
 901 N. Broadway • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 procurementinfo@kcdc.org
 www.kcdc.org

Addendum

| | | | | | |
|--------------------------|--|------------------------|---|-------------|----------|
| Solicitation Name | Concrete Work at the Cagle Terrace Parking Lot Q2219 | Addendum Number | 1 | Date | 06/03/22 |
|--------------------------|--|------------------------|---|-------------|----------|

This addendum answers questions raised about this solicitation. Questions are generally verbatim as received. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

| | |
|----|---|
| Q1 | The drawings show a landscape strip separating the new concrete slope with the existing concrete. This is on both entrances. Is it acceptable to use railings where the landscape strips were going to be? |
| | Yes. The specifications for the railings are ADA compliant, round tubing 2.5" (minimum) top and mid-rail, color black, between or just outside of the canopy posts. Approximately 14' on the South ADA parking plan and approximately 20' on the North ADA parking plan. |
| Q2 | Would KCDC like to have bidders add a \$10,000 contingency to their bid with the stipulation that it be credited back to KCDC if not used? |
| | Yes. |

