

ADDENDUM NO. I

BID NUMBER: 305959

BID TITLE: Sewer Pipe

DEPARTMENT: Waste Resources Division, Public Works

DATE OF ADDENDUM: August 14, 2020

BID DUE DATE: August 18, 2020

BID DUE TIME: 2:00 p.m., e.s.t.

REASON: ANSWERS TO QUESTIONS

Q. They have listed both Fastite and Tyton joint ductile iron pipe, those are the same product only made by different manufactures. We could only quote the Fastite, will we be penalized for not quoting the entire list?

A. We can use either Tyton or Fastite as long as the pipe is the correct size. You can bid either.

Q. They have listed "mechanical joint" ductile iron pipe, which is an outdated joining process and if they are used to push joint do they really want any "mechanical joint" and if it's not made any more in certain sizes will we be penalized for not quoting it?

A. We mainly use the push joint type. The mechanical joint is something we may use for a high pressure situation. Lines 74-82 on the bid document reads Mechanical joint, when submitting your bid, bid those lines as push type instead of mechanical joint.

Q. Do you anticipate extending the bid due date?

A. No.

Q. What additional details are you willing to provide, if any, beyond what is stated in bid documents concerning how you will identify the winning bid?

A. Award will be made to best bid meeting specifications.

Q. Was this bid posted to the nationwide free bid notification website at www.mygovwatch.com/free?

A. No.

Q. Other than your own website, where was this bid posted?

A. The local newspaper, Chattanooga Times.

(SIGNED): _____(DATE): _____

(COMPANY): _____

Please sign one (1) copy of this page and return it with your proposal, or separately and clearly labelled if your proposal has already been submitted, to the Purchasing Department (email: aberkowitz@chattanooga.gov; or fax to 423-643-7244 Attn: A Berkowitz; or mail to Purchasing Dept., Attn: A Berkowitz, 101 E. 11th Street, Suite G-13, Chattanooga, TN 37402.

Retain a copy for your file.