



RFB2102 Boiling Springs High School Freshman Academy Paving Project

ADDENDUM 1 October 8, 2020

At the mandatory pre-bid meeting on October 8, 2020, the following changes/clarifications were made to the above referenced RFB:

Area 1: While asphalt will stop at existing asphalt, the lines should be restriped all the way to the awning

Area 3: Drive from bollards to rear road will be milled, removing 2" of asphalt and paving 2" surface. The sidewalk will be removed and replaced in all cracked blocks. The concrete pad will be removed and the new area will be paved with 6" asphalt, making it level with road.

Area 4: This area will go from the corner of the building (sidewalk) to the corner of the building and will be 22' deep.

Area 7: The existing damaged sidewalk will be removed and repaired between the C and D wing, as shown in the pre-bid. Please use the attached revised bid response form, which includes this area.

REVISED BID RESPONSE FORM
BOILING SPRINGS FRESHMAN ACADEMY PAVING

Area 1: Bus Entrance \$ _____

Area 2: Dumpster Pads/Parking \$ _____

Area 3: Beside Cheerleading Room \$ _____

Area 4: Teacher Parking \$ _____

Area 5: Practice Field Path \$ _____

Area 6: Baseball field parking area \$ _____

Area 7: Sidewalk between C and D wings \$ _____

TOTAL PRICE: \$ _____

Alternates

Area 1A – Bus Entrance Stone \$ _____

Area 2A – Dumpster/Parking Stone \$ _____

Area 4A – Teacher Parking Curb \$ _____

Area 6A – Baseball Parking Curb \$ _____

Pricing above to include all labor, travel, parts, equipment and all other charges. The District will not be responsible for any other charges or fees.

Bidder/Company name (Please print): _____

Authorized Signature & Date: _____

SC License#: _____

Name of License Holder: _____