

Arlington County Public School
Facilities Warehouse
2770 S Taylor St

Building: Arlington County Public School Facilities Warehouse			
Device or Item	Category		Quantity
Power Supply	Control		1
Communicator	Control		1
Batteries	Control		2
Interface	Access		1
Device or Item	Qty	Model #	Description
Lenel			
Communicator	1	LNL-2220	Network
Interface	1	LNL-1320-S3	
Life Safety			
Power Supply	1	FPO150	
Ultratech			
Batteries	2	UT-1270	Sealed Lead Acid

Arlington Police Warehouse
 2704 S Oakland Street
 2706 S Oakland Street

Building: ARLINGTON POLICE WAREHOUSE			
Device or Item	Category		Quantity
Batteries	Control		1
Client	Control		1
Control Panel	Control		1
Door Contact	Alarm		6
Keypad	Control		2
Motion Sensor	Alarm		4
Device or Item	Qty	Model #	Description
Bosch			
Client	1	D8128D	Expander
Door Contact	1		Magnetic
Door Contact	2	1078	Magnetic
Motion Sensor	4	1260	Dual Technology
DMP			
Control Panel	1	XR150	Security
Keypad	2	7872-W	Security
GS			
Batteries	1	PE12V7.2	Sealed Lead Acid
Sentrol			
Door Contact	2	2207A	Magnetic
Door Contact	1	2207A-L	Magnetic

Arlington Mill Community Ctr

909 S. Dinwiddie Street

Building: Arlington Mill Community Ctr			
Device or Item	Category		Quantity
Batteries	Control		18
Camera	Video		32
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		25
Interface	Access		28
Keypad	Control		4
Motion Sensor	Alarm		20
Power Supply	Control		26
Reader	Access		41
Device or Item	Qty	Model #	Description
Altronix			
Power Supply	2	AL1012ULACM CB	
Axis Communications			
Camera	1	P3245-LVE	Color
Camera	1	P3245-V	Color
Camera	1	P3245-VE	Color
Bosch			
Interface	1	D8125	
Interface	2	D8128D	
Motion Sensor	20	DS835	Dual Technology
DMP			
Control Panel	1	XR150	
Interface	1	263EXT	Automatic
Interface	1	736P	Automatic
Keypad	4	7872-W	Security
HID			
Reader	1	910PTPNEK000 FC	Proximity
Reader	40	920PTPNEK000 FC	Proximity
Lenel			
Communicator	1	LNL-2220	Network
Interface	2	LNL-1300e	
Interface	20	LNL-1320-S3	
Interface	1	Lnl-1320-S3	
Life Safety			
Power Supply	4	C8	
Power Supply	4	D8P	
Power Supply	2	FPO150	
Power Supply	2	FPO250	

Device or Item	Qty	Model #	Description
Life Safety power			
Power Supply	4	C8	
Power Supply	4	D8P	
Power Supply	2	FPO150	
Power Supply	2	FPO250	
Pelco			
Camera	1	IM10C10- ACQTKZ1	Color
Camera	6	IMP1110-1ER	Color
Sentrol			
Door Contact	25	1076	Magnetic
UltraTech			
Batteries	7	UT-1270	Sealed Lead Acid
Universal battery			
Batteries	11	UB1270K	Sealed Lead Acid

ART Bus Light Maintenance Facility 3201 S Eads Street

Building: ART BUS FACILITY			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		35
Communicator	Control		1
Intercom	Personnel		3
Interface	Access		10
Power Supply	Control		2
Reader	Access		20
Device or Item	Qty	Model #	Description
Aiphone			
Intercom	2	IX-DF-HID	Network
Intercom	1	IX-MV	Network
Awid			
Reader	2	LR2000	Proximity
Axis Communications			
Camera	1	M3027	POE
Camera	12	M3027-PVE	POE
Camera	1	M3207-PVE	POE
HID			
Reader	15	920PTPNEK000 FC	Proximity
Lenel			
Communicator	1	LNL-2220	IP
Interface	10	LNL-1320-S3	Automatic
Life Safety			
Power Supply	2	FPO150	
Linear			
Reader	3	WOR	Proximity
Pelco			
Camera	3	IMM12027	POE
Camera	18	IMP321-1RS	POE
Power Sonic			
Batteries	4	PS-1270 F1	Sealed Lead Acid

ART House III

2900 S EADS STREET

Building: ART HOUSE III				
Device or Item	Category			Quantity
Batteries	Control			3
Camera	Video			7
Communicator	Control			3
Control Panel	Control			1
Door Contact	Alarm			2
Interface	Access			1
Keypad	Control			1
Module	Control			2
Motion Sensor	Alarm			9
Power Supply	Control			1
Reader	Access			5
Device or Item	Qty	Model #	Description	Install Date
Axis Communications				
Camera	2	P3048-P	POE	
Camera	3	P3225-V MkII	POE	
Camera	1	P3225-VE MkII	POE	
Camera	1	P3807-PVE	POE	
Bosch				
Module	1	D8125	Popit Module	
Motion Sensor	1	DS835IT	Dual Technology	
Motion Sensor	8	ZX935Z	Dual Technology	
DMP				
Communicator	1	263LTE	Cellular	
Control Panel	1	XR150	Security	
Keypad	1	7872-W	Security	
Module	1	736P	Translator	
HID				
Reader	5	920PTPNEK000 FC	Proximity	
Interlogix				
Door Contact	2	1076D-N	Magnetic	
Lenel				
Communicator	1	LNL-2220	IP	
Communicator	1	LNL-X2220		
Interface	1	LNL-1320		
Life Safety power				
Power Supply	1	FPO150		
Universal battery				
Batteries	3	UB1270K	Sealed Lead Acid	

Barcroft Sports Complex And Garage 4200 S Four Mile Drive

Building: Barcroft Sports & Fitness Ctr - GARAGE			
Device or Item	Category		Quantity
Telephone	Control		7
Device or Item	Qty	Model #	Description
Talk-A-Phone			
Telephone	1	EC-8	Emergency
Telephone	5	ETP-400	Emergency
Telephone	1	ETP-500E	Emergency

Building: Barcroft Sports & Fitness Ctr			
Device or Item	Category		Quantity
Batteries	Control		1
Camera	Video		4
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		8
Keypad	Control		1
Module	Control		2
Motion Sensor	Alarm		11
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	1	P3245-LV	
Camera	3	P3245-LV	POE
Ademco			
Door Contact	8	7939	Magnetic
Bosch			
Module	1	D8125	Group Control
Motion Sensor	1	DS835i	Dual Technology
Motion Sensor	1	DS970	Dual Technology
Motion Sensor	1	DT835i	Dual Technology
C&K			
Motion Sensor	4	DT-660STC	Dual Technology
Motion Sensor	1	DT-706	Dual Technology
Motion Sensor	1	DT-906	Dual Technology
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security

Keypad	1	7872-W	Security
Module	1	736P	Group Control
Honeywell			
Motion Sensor	1	DT-7435	Dual Technology
Motion Sensor	1	DT7435	Dual Technology
Universal Battery			
Batteries	1	UB1270K	Sealed Lead Acid

Courthouse Plaza (Bozman Bldg)

2100 Clarendon Blvd

Building: COURTHOUSE PLAZA (BOZMAN BLDG)			
Device or Item	Category		Quantity
Audible	Control		2
Batteries	Control		64
Communicator	Control		5
Camera	Video		30
Interface	Access		130
Power Supply	Control		38
Reader	Access		211
Device or Item	Qty	Model #	Description
HID			
Audible	1	910PTPNEK000 FC	
Audible	1	920PTPNEK000 FC	
Reader	22	910PTPNEK000 FC	Proximity
Reader	1	920PTPNEK000 FC	
Reader	188	920PTPNEK000 FC	Proximity
Lenel			
Communicator	1	LNL-2220	
Communicator	1	LNL-X2220	
Communicator	3	LNL-X2220	IP
Interface	7	LNL-1100-S3	
Interface	7	LNL-1200-S3	
Interface	7	LNL-1300	
Interface	109	LNL-1320-S3	
Life Safety power			
Power Supply	30	FPO150	
Power Supply	8	FPO250	
Power sonic			
Batteries	44	PS-1270-F1	
Batteries	20	PS-1270-F1	Sealed Lead Acid

Building: Office of the Treasurer (Bozman)			
Device or Item	Category		Quantity
Batteries	Control		8
Button	Alarm		55
Camera	Video		29
Communicator	Control		1
Control Panel	Control		3
Door Contact	Alarm		1

Device or Item	Category	Quantity
Interface	Access	20
Keypad	Control	12
Motion Sensor	Alarm	10
Power Supply	Control	5
Reader	Access	24

Device or Item	Qty	Model #	Description
DMP			
Motion Sensor	10	1126R-W	Passive Infrared

Axis			
Camera	6	M3058-PLVE	POE
Camera	7	P3225-V MkII	POE
Camera	3	P3245-LVE	POE

Axis Communications			
Camera	7	M3058-PLVE	POE
Camera	1	P3225-V MKII	POE
Camera	1	P3225-V Mk II	POE
Camera	1	P3225-V MkII	POE
Camera	1	P3225-V MkII	POE
Camera	1	P3245-LVE	POE

Bosch			
Interface	8	D8128D Zone Expand	Manual

DMP			
Control Panel	1	XR550	Security
Keypad	11	7872-W	Security

GE Security			
Button	53	3040-W	Hold-Up
Communicator	1	ADC-200H-EVD	Cellular

Building: BOZMAN COUNTY LIBRARY PRT 1

Device or Item	Category	Quantity
Batteries	Control	1
Button	Alarm	6
Communicator	Control	1
Control Panel	Control	1
Keypad	Control	1
Receiver	Control	1

Device or Item	Qty	Model #	Description
DMP			
Button	6	1142W	Panic
Communicator	1	263LTE	
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Receiver	1	1100XH	

Universal Battery			
Batteries	1	UB1270	Sealed Lead Acid

Building: ARLINGTON COUNTY 10TH FLOOR (Bozman)

Device or Item	Category		Quantity
Camera	Video		7
Device or Item	Qty	Model #	Description
Pelco			
Camera	7	IMP1110-1ER	POE

Cultural Affairs Building

3700 S. Four Mile Run

Building: Cultural Affairs Building			
Device or Item	Category		Quantity
Batteries	Control		4
Button	Alarm		3
Communicator	Control		2
Control Panel	Control		1
Door Contact	Alarm		12
Keypad	Control		2
Module	Control		3
Motion Sensor	Alarm		13
Power Supply	Control		3
Reader	Access		2
Device or Item	Qty	Model #	Description
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	2	7872-W	Security
Module	3	714-8	
ESD			
Power Supply	1	SPS-5	
GE			
Button	3	Interlogix 3040-W	
Door Contact	8	Interlogix 1078C-N	
Door Contact	4	Interlogix 3040-W	Magnetic
Motion Sensor	13	Interlogix AP669	Passive Infrared
HID			
Reader	2	920PTPNEK000 FC	Smart Reader
Lenel			
Communicator	1	LNL-2220	Ethernet Transceiver
Life Safety Power			
Power Supply	1	FPO150-B100C 8PE6M	
Power Sonic			
Batteries	2	PS-1270 F1	Sealed Lead Acid
Security Door Control			

Power Supply	1	602RF
--------------	---	-------

Universal Battery

Batteries	2	UB1270r	Sealed Lead Acid
-----------	---	---------	------------------

Equipment Bureau

2701 S Taylor St

Building: Equipment Bureau			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		26
Communicator	Control		1
Console	Control		1
Control Panel	Control		2
Door Contact	Alarm		14
Interface	Access		7
Keypad	Control		3
Motion Sensor	Alarm		10
Power Supply	Control		7
Reader	Access		12
Device or Item	Qty	Model #	Description
ESD			
Power Supply	1	SPS-5	
HID			
Reader	3	920PTPNEK000 FC	Proximity
Lenel			
Console	1	LNL-X2220	
Interface	1	LNL-1320-S3	
Interface	1	LNL-1320-S3	Manual
Life Safety			
Power Supply	1	8100/D8P	
Power Supply	1	C8	
Power Supply	1	FPO150	
APC			
Power Supply	1	Back UPS RS 1500	UPS
Axis Communications			
Camera	1	M3707	Color
Camera	5	M3707-PE	Color
Camera	1	P3057- PL	Color
Camera	5	P3057- PLVE	Color
Camera	2	P3225-LV Mk II	Color
Camera	2	P3367	Color
Bosch			
Interface	1	D8125	Automatic
Motion Sensor	2	DS835	Dual Technology
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security

Keypad	3	7872-W	Security
GeoVision			
Camera	1	GV-IP LPR Camera	Black/White
HID			
Reader	9	920PTPNEK000 FC	Proximity
Lenel			
Control Panel Interface	1	LNL-2220	Access Control
Interface	2	LNL-1320-S3	
Interface	2	LNL-1320-S3	Automatic
Life Safety			
Power Supply	1	D8P	
Power Supply	1	FPO75	
Optex			
Motion Sensor	8	LX-402	Dual Technology
Pelco			
Camera	2	IM10DN10-1V- ADPGQ1	Color
Camera	1	IM10DN10-1V- ADPGQ3	Color
Camera	2	IM10DN10-1V- ADPGQ4	Color
Camera	1	IMP421-1RS	Color
Camera	1	INP219-ER-T4 140682	Color
Camera	1	Optera	POE
Camera	1	Sarix Pro2	POE
Sentrol			
Door Contact	10	1078C	Magnetic
Door Contact	3	2207A	Magnetic
Door Contact	1	2505A	Magnetic
Ultratech			
Batteries	1	UT-1270	Sealed Lead Acid
Utc			
Batteries	3	UT 1270	Sealed Lead Acid

Fairlington Community Center

3308 S Stafford Street

Building: Fairlington Community Center			
Device or Item	Category		Quantity
Batteries	Control		6
Client	Control		1
Control Panel	Control		2
Door Contact	Alarm		18
Interface	Access		9
Keypad	Control		3
Motion Sensor	Alarm		41
Power Supply	Control		10
Reader	Access		19
Device or Item	Qty	Model #	Description
Alarm Saf			
Power Supply	1	PS-12025-B04 -UL	
Bosch			
Motion Sensor	38	DS860	Dual Technology
Motion Sensor	1	DS937	Passive Infrared
Motion Sensor	2	DS9370	Dual Technology
DMP			
Client	1	736P	Translator
Control Panel	1	XR150	Security
Door Contact	1	1103-W	
Keypad	3	7872-W	Security
HID			
Reader	1	910PTPNEK000 FC	Proximity
Reader	18	920PTPNEK000 FC	Proximity
Lenel			
Control Panel	1	LNL-2220	Access Control
Interface	9	LNL-1320	
Life Safety power			
Power Supply	2	C8	
Power Supply	3	D8P	
Power Supply	2	FPO150	
Power Supply	1	FPO75	
Sentrol			
Door Contact	7	1076	
Door Contact	10	1076	Magnetic
UltraTech			
Batteries	1	UT-1270	Sealed Lead Acid

Universal battery

Batteries	1	UB1270	Sealed Lead Acid
Batteries	4	UB1270K	Sealed Lead Acid

Von Duprin

Power Supply	1	PS914	
--------------	---	-------	--

QUINCY I

1425 N Quincy Street

Building: QUINCY I			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		10
Keypad	Control		2
Device or Item	Qty	Model #	Description
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	2	7872-W	Security
Sentry			
Door Contact	10		Magnetic
Universal Battery			
Batteries	1	UT1270	Sealed Lead Acid

Sequoia Plaza I
2100 Washington Blvd.

Building: 2100 Washington Blvd.			
Device or Item	Category		Quantity
Camera	Video		3
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	1	M3058-PLVE	POE
Camera	1	M3227-LVE	POE
Camera	1	M3807-PVE	POE

Sequoia Plaza II
2110 Washington Boulevard

Building: 2110 Washington Boulevard			
Device or Item	Category		Quantity
Camera	Video		2
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	2	P3227-LVE	POE

Sequoia Plaza III 2120 Washington Blvd.

Building: 2120 Washington Blvd.			
Device or Item	Category		Quantity
Camera	Video		8
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	1	M3058-PLVE	POE
Camera	2	P3807-PVE	POE
Camera	1	P4206-V	POE
Pelco			
Camera	3	IM10LW10-1V	POE
Camera	1	IMP1110-1ER	POE

Shirlington Library

4200 Campbell Ave

Building: Shirlington Library Signature				
Device or Item	Category			Quantity
Batteries	Control			2
Button	Alarm			1
Camera	Video			3
Communicator	Control			1
Control Panel	Control			1
Door Contact	Alarm			4
Interface	Access			1
Keypad	Control			3
Motion Sensor	Alarm			7
Power Supply	Control			1
Receiver	Control			1
Device or Item	Qty	Model #	Description	
Altronix				
Power Supply	1	AL600U		
Axis Communications				
Camera	2	M3048-P	POE	
Camera	1	P3374-V	POE	
Bosch				
Motion Sensor	6	DS835	Dual Technology	
DMP				
Button	1	1142	Hold-Up	
Communicator	1	263LTE	Cellular	
Control Panel	1	XR150	Security	
Interface	1	714-8	Zone Expander	
Keypad	3	7872-W	Security	
Receiver	1	1100XH	Security	
Honeywell				
Motion Sensor	1	IS 2535	Passive Infrared	
Sentrol				
Door Contact	4	1076	Magnetic	
Universal battery				
Batteries	2	UB1270	Sealed Lead Acid	

Solid Waste/TE&O Bldg

4290 S 29th Street

Building: Solid Waste/TE&O			
Device or Item	Category		Quantity
Batteries	Control		5
Camera	Video		14
Client	Control		8
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		9
Interface	Access		8
Keypad	Control		3
Motion Sensor	Alarm		4
Power Supply	Control		2
Reader	Access		15
Router	Video		1
Device or Item	Qty	Model #	Description
Universal Battery			
Batteries	4	UB1270	Sealed Lead Acid
Axis			
Camera	1	P3818-PVE	POE
Axis Communications			
Camera	1	M3007-PVE	POE
Camera	2	M3037-PVE	Color
Camera	1	P-3807-PVE	POE
Camera	1	P3807-PVE	POE
Bosch			
Motion Sensor	4	DS835i	Dual Technology
DMP			
Control Panel	1	XR150	Security
Interface	1	714-8	Zone Expander
Keypad	1	7872-W	
Keypad	2	7872-W	Security
HID			
Reader	4	910PTPNEK000 FC	Proximity
Reader	11	920PTPNEK000 FC	Proximity
Lenel			
Communicator	1	LNL-2220	IP Network
Interface	7	LNL-1320-S3	Automatic
Life Safety power			
Power Supply	1	FPO150	
Power Supply	1	FPO250	

Luxul			
Router	1	XMS-2624P	
NanoStaion			
Client	2	M5	
NanoStation			
Client	2	M5	Digital
Pelco			
Camera	6	IMP-321	POE
Camera	1	IXE10DN	POE
Camera	1	Spectra D5118	POE
Rocket			
Client	2	M5	
Sentrol			
Door Contact	1		Magnetic
Door Contact	7	1076	Magnetic
Door Contact	1	2202	Magnetic
UltraTech			
Batteries	1	UT-1270	Sealed Lead Acid
Volo			
Client	2	Configurator	Digital

Sullivan House

3103 N 9th Road

Building: Sullivan House			
Device or Item	Category		Quantity
Batteries	Control		1
Camera	Video		7
Control Panel	Control		1
Door Contact	Alarm		2
Keypad	Control		1
Window Contact	Alarm		3
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	2	M3024-L	POE
Camera	3	M3027	POE
Camera	2	P3265-V	POE
DMP			
Control Panel	1	XR150	Security
Keypad	1	7278-W	Security
Honeywell			
Door Contact	2	7939w	Magnetic
Window Contact	3	7939w	Magnetic
Universal Battery			
Batteries	1	UB-1270	Sealed Lead Acid

WSS Storage

4250 28th Street South

Building: WSS Storage			
Device or Item	Category		Quantity
Camera	Video		9
Client	Control		2
Power Supply	Control		1
Router	Video		1
Device or Item	Qty	Model #	Description
APC			
Power Supply	1		
Axis			
Camera	1	P3818-PVE	POE
Axis Communications			
Camera	1	M3027	POE
Camera	1	M3058-PLVE	POE
Camera	1	P1365 MkII	POE
Camera	1	P3818-PVE	POE
Fluidmesh			
Client	2	Volo FM1200	Wireless Network Tra
Luxul			
Router	1	XMS-2624P	Digital
Pelco			
Camera	4	IMP321-1RS	POE

Carlin Hall

5711 South 4th St

Building: Carlin Hall			
Device or Item	Category		Quantity
Camera	Video		3
Client Station	Control		2
Network Switch	Control		1
Device or Item	Qty	Model #	Description
Axis			
Camera	3	P3818-PVE	POE
Network Switch	1	D8004	PoE
Fluidmesh			
Client Station	2	Ponte	Wireless Transceiver

Airport Plaza

2711 Jefferson Davis Highway

Building: Airport Plaza			
Device or Item	Category		Quantity
Batteries	Control		2
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		4
Interface	Access		4
Keypad	Control		2
Motion Sensor	Alarm		3
Power Supply	Control		2
Device or Item	Qty	Model #	Description
APC			
Power Supply	1	Back UPS 1500	UPS
Altronix			
Power Supply	1	AL600ULX	
Bosch			
Motion Sensor	1	DS939	Dual Technology
Motion Sensor	2	Ds930i	Dual Technology
DMP			
Interface	1	734	Semi-Automatic
Keypad	1	7872-W	Security
Dmp			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Interface	3	734	Semi-Automatic
Keypad	1	7872-W	Security
Power Sonic			
Batteries	2	PS-1270 F1	Sealed Lead Acid
Sentrol			
Door Contact	4	1078C	Magnetic

Arlington Arts Center

3553 Wilson Blvd

Building: Arts Center			
Device or Item	Category		Quantity
Batteries	Control		2
Camera	Video		19
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		16
Intercom	Personnel		2
Interface	Access		7
Keypad	Control		3
Motion Sensor	Alarm		11
NVR	Video		1
Network Switch	Control		1
Power Supply	Control		1
Reader	Access		3
Video Monitor	Video		1
Device or Item	Qty	Model #	Description
TP-Link			
Network Switch	1	TL-SL-2428P	PoE
Wisenet			
Camera	2	QND-6012R1	POE
Altronix			
Power Supply	1	AL400ULM	
Bosch			
Interface	3	D8128D	
Motion Sensor	11	DS835	Dual Technology
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Interface	3	734	
Interface	1	736P	Popit Translator
Keypad	3	7872-W	Security
HID			
Reader	3	5395CG100	Proximity
Samsung			
Video Monitor	1	C27F390FH	Color
Sentrol			
Door Contact	9	1076	
Door Contact	7	1076	Magnetic

UltraTech			
Batteries	2	UT-1270	Sealed Lead Acid
Viking			
Intercom	2	C-1000A	
Wisenet			
Camera	14	QND-2010R1	POE
Camera	1	QNF-8010	POE
Camera	1	QNV-7082R	POE
Camera	1	XNF-8010RV	POE
NVR	1	XRN-2010A	Combination

Aurora Hills

735 18th Street S.

Building: Aurora Hills			
Device or Item	Category		Quantity
Batteries	Control		1
Button	Alarm		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		7
Keypad	Control		2
Module	Control		1
Motion Sensor	Alarm		5
Device or Item	Qty	Model #	Description
DMP			
Communicator	1	263LTE	Cellular
Bosch			
Motion Sensor	5	DS835i	Dual Technology
DMP			
Control Panel	1	XR150	Security
Keypad	2	7872-W	Security
Module	1	714-8	
Linear			
Button	1	D-22B	Panic
Sentrol			
Door Contact	3	1076	Magnetic
Door Contact	4	2707A	Magnetic
Universal battery			
Batteries	1	UB1270	Sealed Lead Acid

Central Library

1015 N Quincy Street

Building: CENTRAL LIBRARY			
Device or Item	Category		Quantity
Batteries	Control		3
Button	Alarm		7
Camera	Video		10
Control Panel	Control		1
Door Contact	Alarm		7
Interface	Access		3
Keypad	Control		1
Motion Sensor	Alarm		3
Power Supply	Control		1
Reader	Access		5
Receiver	Control		1
Device or Item	Qty	Model #	Description
HID			
Reader	1	910PTPNEK000 FC	Proximity
Reader	1	920PTPNEK000 FC	Proximity
Reader	3	921PTPNEK000 FD	Proximity/Pin
Lenel			
Interface	2	LNL-1320-S3	
Interface	1	LNL-2220	
Ultratech			
Batteries	3	UT 1270	Sealed Lead Acid
Button	5		Panic
Axis Communications			
Camera	4	M3047-P	POE
Camera	1	P3225-V Mk II	POE
Camera	4	P3818-PVE	POE
Camera	1	Q6125-LE PTZ	POE
DMP			
Button	2	1142	Panic
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Motion Sensor	3	1126R-W	Passive Infrared
Receiver	1	1100XH	Security
Life Safety Power			
Power Supply	1	FPO150	
Sentrol			
Door Contact	7	1085T	Magnetic

Cherrydale Library

2190 Military RD

Building: Cherrydale Library			
Device or Item	Category		Quantity
Batteries	Control		1
Control Panel	Control		1
Door Contact	Alarm		4
Keypad	Control		2
Module	Control		3
Motion Sensor	Alarm		5
Device or Item	Qty	Model #	Description
Bosch			
Module	1	711	Network Interface
Motion Sensor	4	ISC-BDL2-W12 G	Dual Technology
DMP			
Control Panel	1	XR150	Security
Keypad	2	7278-W	Security
Module	2	711	Network Interface
DSC			
Motion Sensor	1	BV-600	Dual Technology
Sentrol			
Door Contact	2	1078	Magnetic
Door Contact	1	1085T	Magnetic
Door Contact	1	Tamper	Magnetic
Universal Battery			
Batteries	1	UB1270K	Sealed Lead Acid

Clarendon House

3141 10th Street, North

Building: Clarendon House			
Device or Item	Category		Quantity
Control Panel	Control		1
Keypad	Control		1
Batteries	Control		1
Motion Sensor	Alarm		4
Door Contact	Alarm		4
Device or Item	Qty	Model #	Description
C&K			
Motion Sensor	4	DT660STC	Dual Technology
power Sonic			
Batteries	1	PS-1270	Sealed Lead Acid
Radionics			
Control Panel	1	D7412	
Keypad	1	D1255	Security
Sentrol			
Door Contact	4	1076	Magnetic

Commuter Store
1501 Wilson Blvd
11th Floor

Building: COMMUTER STORE			
Device or Item	Category		Quantity
Batteries	Control		1
Control Panel	Control		1
Power Supply	Control		1
Reader	Access		1
Device or Item	Qty	Model #	Description
HID			
Reader	1	920PTPNEK000 FC	Proximity
Lenel			
Control Panel	1	LNL-X2220	Access Control
Life Safety power			
Power Supply	1	FPO75	
Power sonic			
Batteries	1	PS-1270 F1	Sealed Lead Acid

Court Square West 1400 N Uhle St

Device or Item	Category		Quantity
Batteries	Control		5
Button	Alarm		4
Camera	Video		12
Communicator	Control		1
Control Panel	Control		1
Interface	Access		22
Keypad	Control		1
Power Supply	Control		15
Reader	Access		36
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	1	M3707-PE	POE
Oncam			
Camera	1	Grandeye	POE
Altronix			
Power Supply	1	SMP3	
Axis Communications			
Camera	1	M3045-V	POE
Camera	5	P3225-LVE Mk II	POE
Camera	1	P3225-V Mk II	POE
Camera	1	P3245-LV	POE
Camera	1	P3245-LVE	POE
Camera	1	P3807-PVE	POE
DMP			
Button	4	1142	Panic
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Electronic Security			
Power Supply	7	PDM-8	
Power Supply	4	SPS-5/F	
HID			
Reader	1	910PTPNEK000 FC	Wiegand
Reader	1	920PTPNEK000 FC	Proximity
Reader	33	920PTPNEK000 FC	Wiegand
Reader	1	921PTPNEK000 00	Wiegand
Lenel			
Communicator	1	LNL-2220	IP

Device or Item	Qty	Model #	Description
Interface	3	LNL-1200-S3	Automatic
Interface	2	LNL-1300-S3	Automatic
Interface	1	LNL-1320-S2	Automatic
Interface	14	LNL-1320-S3	Automatic
Interface	2	LNL-1320-S3	Manual
Life Safety Power			
Power Supply	1	FPO150	
Power Supply	1	FPO250	
Power Sonic			
Batteries	4	PS-1270	Sealed Lead Acid
Securiton			
Power Supply	1	BPS-24-1	
Universal battery			
Batteries	1	UB1270	Sealed Lead Acid

Building: GIRLS OUTREACH CENTER #303			
Device or Item	Category		Quantity
Batteries	Control		1
Button	Alarm		4
Communicator	Control		1
Control Panel	Control		1
Keypad	Control		1
Receiver	Control		1
Device or Item	Qty	Model #	Description
DMP			
Button	4	1142	Hold-Up
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872W	Security
Receiver	1	1100XH	Security
Universal battery			
Batteries	1	UB1270	Sealed Lead Acid

Dawson Terrace Rec Center

2122 N Taft Street

Building: DAWSON TERRACE REC CENTER			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		1
Keypad	Control		1
Module	Control		2
Motion Sensor	Alarm		4
Device or Item	Qty	Model #	Description
Ademco			
Door Contact	1	7939	Magnetic
Bosch			
Module	1	D8125	
Motion Sensor	3	INS-AP	PIR/Microwave
C&K			
Motion Sensor	1	Dual-tech	PIR/Microwave
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Module	1	736P	
Universal Battery			
Batteries	1	UB1270r	Sealed Lead Acid

Ethan Allen Pumping Station

4451 N Glebe Rd

Building: Ethan Allen Pumping Station			
Device or Item	Category		Quantity
Batteries	Control		3
Camera	Video		4
Communicator	Control		1
Control Panel	Control		2
Door Contact	Alarm		2
Keypad	Control		1
Motion Sensor	Alarm		3
Power Supply	Control		2
Reader	Access		1
Router	Video		1
Device or Item	Qty	Model #	Description
Apc			
Power Supply	1	SMT1000RM2U	
Axis Communications			
Camera	1	M3707PE	Color
Camera	1	P3225-LV	Color
Camera	1	P3225PVE	Color
Cisco			
Router	1	WS-C3560C-1 2PC-S	
HID			
Reader	1	920PTPNEK000 FC	Proximity
Pelco			
Camera	1		Color
Power Sonic			
Batteries	1	PS-1280 F1	Sealed Lead Acid
Power sonic			
Batteries	1	PS-1280 F1	
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Lenel			
Control Panel	1	LNL-2220	Access Control
Life Safety power			
Power Supply	1	FPO-75	
Optex			
Motion Sensor	3	LX-402	Passive Infrared

Sentrol

Door Contact	1	1078C	Magnetic
Door Contact	1	2207	Magnetic

Ultratech

Batteries	1	UT-1270	Sealed Lead Acid
-----------	---	---------	------------------

Fort Barnard

2101 South Pollard Street

Building: FORT BARNARD			
Device or Item	Category		Quantity
Batteries	Control		3
Camera	Video		2
Communicator	Control		1
Control Panel	Control		2
Door Contact	Alarm		1
Keypad	Control		1
Motion Sensor	Alarm		1
Power Supply	Control		2
Reader	Access		1
Router	Video		1
Device or Item	Qty	Model #	Description
HID			
Reader	1	920PTPNEK000 FC	Proximity
Life Safety			
Power Supply	1	FPO75	
Ultratech			
Batteries	1	UT-1270	Sealed Lead Acid
Apc			
Power Supply	1	SMT1000RM2U	
Cisco			
Router	1	Catalyst 3560C Ser	Digital
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Lenel			
Control Panel	1	LNL-2220	Access Control
Optex			
Motion Sensor	1	LX-402	Dual Technology
Pelco			
Camera	1	IMP1110-1ER	Color
Camera	1	IXE21	Color
Sentrol			
Door Contact	1	2507AD-L	Magnetic
UltraTech			
Batteries	2	UT-1270	Sealed Lead Acid

Fort CF Smith Park
Main House & Barn
2411 N 24th Street

Building: Fort CF Smith Park - Main House & Barn			
Device or Item	Category		Quantity
Batteries	Control		2
Client	Control		1
Control Panel	Control		2
Door Contact	Alarm		6
Keypad	Control		5
Motion Sensor	Alarm		11
Sensor	Alarm		1
Device or Item	Qty	Model #	Description
Bosch			
Motion Sensor	2	DS9360	Dual Technology
C&K			
Motion Sensor	9	DT-450TC	Dual Technology
DMP			
Client	1	716-8	Expander
Control Panel	2	XR150	Security
Keypad	1	7872-W	
Keypad	4	7872-W	Security
Pama			
Sensor	1	GHD 2000	Gas
Sentrol			
Door Contact	6	1078C	Magnetic
Universal battery			
Batteries	1	UB1270K	Sealed Lead Acid
Yuasa			
Batteries	1	NP7.5-12	Sealed Lead Acid

Glen Carlyn Library

300 S Kensington Street

Building: Glen Carlyn Library			
Device or Item	Category		Quantity
Batteries	Control		1
Control Panel	Control		1
Door Contact	Alarm		2
Interface	Access		6
Keypad	Control		1
Module	Control		1
Motion Sensor	Alarm		4
Device or Item	Qty	Model #	Description
DMP			
Module	1	736P	Network Interface
Bosch			
Interface	5	D9127U	
Motion Sensor	3	ISC-BDL2-W12 G	Dual Technology
DMP			
Control Panel	1	XR150	Security
Keypad	1	7278-W	Security
Honeywell			
Motion Sensor	1	DT730	Dual Technology
Radionics			
Interface	1	D9127U	
Sentrol			
Door Contact	2	1085	Magnetic
Universal Battery			
Batteries	1	UB1270K	Sealed Lead Acid

Glen Carlyn Park

301 S Harrison St

Building: GLEN CARLYN PARK			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Electric Lock	Access		2
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Electric Lock	2		Cylindrical
Altronix			
Power Supply	1	AL300ULX	
Brivo			
Communicator	1		Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTPNEK000 FC	Proximity
Power sonic			
Batteries	1	PS-1270 F1	Sealed Lead Acid

Gulf Branch Nature Center

3608 Military Road

Building: Gulf Branch Nature Center			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		1
Interface	Access		7
Keypad	Control		1
Module	Control		2
Motion Sensor	Alarm		6
Device or Item	Qty	Model #	Description
Bosch			
Interface	7	D9127U	
Keypad	1	D1255	Security
Module	1	D8125	Group Control
Motion Sensor	5	INS-AP Series	Dual Technology
Motion Sensor	1	S 115A	Microwave
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Module	1	736P	Group Control
Power sonic			
Batteries	1	PS-1270 F1	Sealed Lead Acid
Sentrol			
Door Contact	1	1076	Magnetic

Hayes Park

1516 N. Lincoln St

Building: HAYES PARK			
Device or Item	Category		Quantity
Communicator	Control		1
Control Panel	Control		1
Magnetic Lock	Access		2
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Altronix			
Power Supply	1	AL300ULX	Fail Safe
Brivo			
Communicator	1	B-OA-CNM1-Z 1	Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTNNEK00 000	Proximity
Securiton			
Magnetic Lock	2	M680EBDX	Surface

High View Park

1945 N Dinwiddie St

Building: HIGH VIEW PARK			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Magnetic Lock	Access		1
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Altronix			
Power Supply	1	AL300ULX	
Brivo			
Communicator	1		Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTPNEK000 FC	Proximity
Power Sonic			
Batteries	1	PS-1270 FS1	Sealed Lead Acid
Securiton			
Magnetic Lock	1	M62B	Surface

Lee Community Center

5722 Lee Highway

Building: Lee Community Center			
Device or Item	Category		Quantity
Batteries	Control		1
Control Panel	Control		1
Door Contact	Alarm		7
Keypad	Control		3
Module	Control		2
Motion Sensor	Alarm		6
Device or Item	Qty	Model #	Description
C&K			
Motion Sensor	4	DT660	Dual Technology
Motion Sensor	1	DT900	Dual Technology
DMP			
Control Panel	1	XR150	Security
Keypad	3	7872-W	Security
Module	2	715	
Honeywell			
Motion Sensor	1	DT-706C	Dual Technology
Sentrol			
Door Contact	1	1075	Magnetic
Door Contact	5	1076	Magnetic
Door Contact	1	1078	Magnetic
UltraTech			
Batteries	1	UT-1270	Sealed Lead Acid

Lee Pumping station 2400 N Wakefield

Building: Lee Pumping station			
Device or Item	Category		Quantity
Batteries	Control		3
Camera	Video		5
Communicator	Control		1
Control Panel	Control		2
Door Contact	Alarm		1
Enclosure	Video		2
Keypad	Control		1
Motion Sensor	Alarm		2
Power Supply	Control		2
Reader	Access		2
Router	Video		1
Device or Item	Qty	Model #	Description
Axis			
Camera	1	M3058-PLVE	POE
HID			
Reader	2	920PTPNEK000 FC	Proximity
Apc			
Power Supply	1	SMT1000RM2U	
Axis Communications			
Camera	1	Q6125-LE PTZ w/Rad	Color
Cisco			
Router	1	WS-C3560C-1 2PC V01	Digital
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Lenel			
Control Panel	1	LNL-2220	Access Control
Life Safety			
Power Supply	1	FPO75	
Messoa			
Enclosure	2	SLI070HB-P2	
Optex			
Motion Sensor	2	LX-402	Passive Infrared
Pelco			

Camera	1	IMP1110-1ER	Color
Camera	2	IXE21	Color
Power sonic			
Batteries	2	PS-1280 F1	Sealed Lead Acid
Sentrol			
Door Contact	1	1078C	Magnetic
Ultratech			
Batteries	1	UT-1270	Sealed Lead Acid

Little Falls Pumping Station

5012 Little Falls Rd

Building: Little Falls Pumping Station			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		3
Console	Control		1
Control Panel	Control		1
Door Contact	Alarm		1
Keypad	Control		1
Motion Sensor	Alarm		1
Power Supply	Control		2
Reader	Access		1
Router	Video		1
Device or Item	Qty	Model #	Description
Apc			
Power Supply	1	SMT1000RM2U	
Axis Communications			
Camera	2		POE
Cisco			
Router	1	WS-C3560C-1 2PC-S	Digital
Pelco			
Camera	1		Color
Ultratech			
Batteries	2		Sealed Lead Acid
Bosch			
Control Panel	1	D7412G	Security
Keypad	1	D1260	Security
HID			
Reader	1	920PTPNEK000 FC	Proximity
Lenel			
Console	1	LNL-2220	
Life Safety			
Power Supply	1	FPO75	
Optex			
Motion Sensor	1	LC-402	Passive Infrared
Sentrol			
Door Contact	1	1078C	Magnetic
Ultratech			
Batteries	2	UT-1270	Sealed Lead Acid

Long Bridge Aquatic Center

333 Long Bridge Drive

Building: LONG BRIDGE AQUATIC CENTER			
Device or Item	Category		Quantity
Batteries	Control		13
Camera	Video		11
Communicator	Control		1
Control Panel	Control		1
Detector	Alarm		2
Door Contact	Alarm		12
Interface	Access		19
Keypad	Control		3
Main Controller	Control		1
Module	Control		1
Power Supply	Control		6
Reader	Access		39
Receiver	Control		3
Window Contact	Alarm		4
Device or Item	Qty	Model #	Description
DMP			
Communicator	1	263 LTE	Cellular
Control Panel	1	XR150	Security
Detector	2	1103W	Water
Keypad	2	7800	Security
Keypad	1	7800W	Security
Module	1	714-8	Group Control
Receiver	2	1100R	Security
Receiver	1	1100X	Security
Window Contact	4	1103W	Magnetic
HID			
Reader	6	910PTPNEK000 FC	Proximity
Reader	33	920PTPNEK000 FC	Proximity
Interlogix			
Door Contact	6	1078C	Magnetic
Lenel			
Interface	19	LNL-1320-S3	
Main Controller	1	LNL-X2220	Main System
Life Safety power			
Power Supply	2	FPO150	
Power Supply	4	FPO250	
Nascom			
Door Contact	4	1078C	Magnetic
Door Contact	2	OHD Contact	Magnetic

Universal Battery			
Batteries	1	UB1270R	Sealed Lead Acid
Universal Power			
Batteries	4	UB1270r	Sealed Lead Acid
Universal power			
Batteries	4	UB1270R	Sealed Lead Acid
Batteries	4	UB1270r	Sealed Lead Acid
Axis Communications			
Camera	2	M3058-PLVE	POE
Camera	1	P3245-LV	POE
Camera	1	P3245-LVE	POE
Camera	4	P3719-PLV	POE
Camera	1	P3807-PVE	POE
Camera	2	P3818-PVE	POE

Long Branch Nature Center

625 S Carlin Springs Road

Building: Long Branch Nature Center			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		1
Keypad	Control		1
Module	Control		2
Motion Sensor	Alarm		6
Device or Item	Qty	Model #	Description
Bosch			
Module	1	D8125	Group Control
Motion Sensor	1	DS820	Dual Technology
Motion Sensor	4	INS AP	Dual Technology
Motion Sensor	1	ISC-CDL-1-W1 5G	Dual Technology
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Module	1	736	Group Control
Sentrol			
Door Contact	1	1085	Magnetic
UltraTech			
Batteries	1	UT-1270	Sealed Lead Acid

Madison Community Center

3829 N Strafford Street

Building: Madison Community Center			
Device or Item	Category		Quantity
Batteries	Control		1
Control Panel	Control		1
Door Contact	Alarm		3
Interface	Access		2
Keypad	Control		2
Motion Sensor	Alarm		8
Device or Item	Qty	Model #	Description
Bosch			
Motion Sensor	3	DS835	Dual Technology
Motion Sensor	1	DS930	Dual Technology
Motion Sensor	3	INS-AP	Dual Technology
DMP			
Control Panel	1	XR150	Security
Interface	1	736P	Manual
Keypad	2	7872-W	Security
Honeywell			
Motion Sensor	1	DT7435C	Dual Technology
Radionics			
Interface	1	D8125	
Sentrol			
Door Contact	1		Magnetic
Door Contact	2	1078	Magnetic
UltraTech			
Batteries	1	UT-1270	Sealed Lead Acid

Minor Hill Pumping Station

3600 Powhatan St

Building: Minor Hill Pumping Station			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		4
Control Panel	Control		2
Door Contact	Alarm		1
Keypad	Control		2
Motion Sensor	Alarm		1
Power Supply	Control		2
Reader	Access		1
Router	Video		1
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	1	P3245-LVE	POE
Camera	2	Q6135-PE PTZ	POE
Altronix			
Power Supply	1	ALTV244CB	Sealed Lead Acid
Cisco			
Router	1	WS-C3560C-1 2PC-S	Digital
HID			
Reader	1	920PTPNEK000 FC	Proximity
Life Safety			
Power Supply	1	FPO75 w/8100 and C	
Pelco			
Camera	1		Color
Power Sonic			
Batteries	1	PS-1280-F1	Sealed Lead Acid
Bosch			
Control Panel	1	D7412G	Security
Keypad	1	D1260	Security
Keypad	1	D8125INV	Security
Motion Sensor	1	DS930i	Dual Technology
Lenel			
Control Panel	1	LNL-2220	Access Control
Sentrol			
Door Contact	1	2507AD-L	Magnetic
UltraTech			
Batteries	3	UT-1270	Sealed Lead Acid

Nauck Park

2551 S 19th St

Building: NAUCK PARK			
Device or Item	Category		Quantity
Communicator	Control		1
Control Panel	Control		1
Electric Lock	Access		2
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Electric Lock	2		Cylindrical
Altronix			
Power Supply	1	AL300ULX	
Brivo			
Communicator	1		Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTPNEK000 FC	Proximity

Powhatan Springs Skate Park

6020 Wilson Blvd

Building: Powhatan Springs Skate Park			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		2
Keypad	Control		1
Motion Sensor	Alarm		2
Device or Item	Qty	Model #	Description
Bosch			
Motion Sensor	2	DS930i	Dual Technology
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Sentrol			
Door Contact	2	2707A	Magnetic
UltraTech			
Batteries	1	UT-1270	Sealed Lead Acid

Quincy II

1429 N Quincy Street

Building: QUINCY II			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		6
Keypad	Control		1
Device or Item	Qty	Model #	Description
DMP			
Communicator	1	263LTE Cellcom	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
Interlogix			
Door Contact	6	1078	Magnetic
Universal battery			
Batteries	1	UB1270	

Quincy III

1435 N Quincy Street

Building: QUINCY III			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		4
Keypad	Control		1
Motion Sensor	Alarm		2
Receiver	Control		1
Device or Item	Qty	Model #	Description
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Door Contact	4	1101	Wireless
Keypad	1	7872-W	Security
Motion Sensor	1	1127W	Passive Infrared
Motion Sensor	1	1142W	Passive Infrared
Receiver	1	1100D	Security
Universal Battery			
Batteries	1	UT-1270	Sealed Lead Acid

Quincy IV

1439 N Quincy Street

Building: QUINCY IV			
Device or Item	Category		Quantity
Batteries	Control		2
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		7
Keypad	Control		2
Module	Control		2
Motion Sensor	Alarm		11
Power Supply	Control		1
Device or Item	Qty	Model #	Description
Altronix			
Power Supply	1	AL300ULM	Fail Safe
Bosch			
Module	1	D8125	Group Control
Motion Sensor	6	DS720I	PIR/Microwave
Motion Sensor	1	DS830	
Motion Sensor	3	DS830	PIR/Microwave
Motion Sensor	1	DS9360	PIR/Microwave
DMP			
Communicator	1	263LTE	
Control Panel	1	XR150	Security
Keypad	2	7872-W	Security
Module	1	736P	Group Control
Power Sonic			
Batteries	2	PS-1270	Sealed Lead Acid
Sentrol			
Door Contact	7	1078C	Magnetic

Quincy Park

1021 N. Quincy St

Building: QUINCY PARK			
Device or Item	Category		Quantity
Communicator	Control		1
Control Panel	Control		1
Magnetic Lock	Access		2
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Altronix			
Power Supply	1	AL300ULX	Fail Safe
Brivo			
Communicator	1	B-OA-CNM1-Z 1	Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTPNEK000 00	Proximity
Rutherford Controls			
Magnetic Lock	2		Surface

Residential Program Center 1554 Columbia Pike

Building: RESIDENTIAL PROGRAM CENTER			
Device or Item	Category		Quantity
Camera	Video		20
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	6	M3057	POE
Camera	1	P3245-LVE	POE
Camera	1	P3818-PVE	POE
Pelco			
Camera	12	IMP221-1RS	POE

Rocky Run Park

1109 N. Barton St

Building: ROCKY RUN PARK			
Device or Item	Category		Quantity
Batteries	Control		1
Communicator	Control		1
Control Panel	Control		1
Magnetic Lock	Access		2
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Magnetic Lock	2		Surface
Altronix			
Power Supply	1	AL300ULX	
Brivo			
Communicator	1		Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTPNEK000 FC	Proximity
Power sonic			
Batteries	1	PS-1270 F1	Sealed Lead Acid

Thomas Building 2020 N 14th Street

Building: THE THOMAS BUILDING			
Device or Item	Category		Quantity
Batteries	Control		14
Button	Alarm		2
Camera	Video		36
Client	Control		2
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		5
Interface	Access		27
Keypad	Control		3
Motion Sensor	Alarm		2
Power Supply	Control		14
Reader	Access		45
Device or Item	Qty	Model #	Description
Power Sonic			
Batteries	1	PS-1280 F1	Sealed Lead Acid
Batteries	7	PS-1280 F1	Sealed Lead Acid
Bosch			
Keypad	3	D942W	Security
Motion Sensor	2	ISC-BDL2-W12 G	Dual Technology
Interlogix			
Door Contact	1	1078DN	Magnetic
Door Contact	3	1078DN x 2	Magnetic
Door Contact	1	2202	Magnetic
Power sonic			
Batteries	2	PS-1270 F1	Sealed Lead Acid
UTC			
Button	2	3040-W	Hold-Up
Axis Communications			
Camera	1		POE
Camera	2	M3057-PLVE	POE
Camera	3	M3058-PLVE	POE
Camera	2	P3225-V Mk II	POE
Bosch			
Communicator	1	B450/B440	Cellular
Control Panel	1	D9412GV4	Security
Interface	1	D8128D	
Electronic Security			
Power Supply	8	PDM-8	
Power Supply	4	SPS-5	

HID			
Reader	1	910PTPNEK000 FC	Proximity
Reader	44	920PTPNEK000 FC	Proximity
Lenel			
Client	1	LNL-2220	IP
Client	1	LNL-2220	Network
Interface	2	LNL-1200	Automatic
Interface	2	LNL-1300	Automatic
Interface	1	LNL-1320-S3	
Interface	21	LNL-1320-S3	Automatic
Life Safety			
Power Supply	2	FPO150	
Pelco			
Camera	15	IM10LW10-1E	POE
Camera	1	IM10LW10-1V	POE
Camera	1	IME219	POE
Camera	1	IMM12018	POE
Camera	4	IMP1110-1ER	POE
Camera	1	IMP321-1ES	POE
Camera	1	Sarix	
Camera	4	Sarix	POE
Power sonic			
Batteries	2	PS 1280 F1	Sealed Lead Acid
Batteries	1	PS-1270 F1	Sealed Lead Acid
Batteries	1	PS-1270 F2	Sealed Lead Acid

Trade Center NOC

2780 S Taylor St

Building: Trade Center NOC 11			
Device or Item	Category		Quantity
Batteries	Control		3
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		5
Intercom	Personnel		3
Interface	Access		4
Keypad	Control		2
Motion Sensor	Alarm		1
Power Supply	Control		4
Reader	Access		8
Device or Item	Qty	Model #	Description
Aiphone			
Intercom	1	JK-1MED	Video
Intercom	1	JK-DV	Video
Intercom	1	PS-1820	Power Supply
Casil			
Batteries	1	BT126	Sealed Lead Acid
DMP			
Control Panel	1	XR150	Security
Keypad	2	7872-W	Security
HID			
Reader	8	920PTPNEK000 FC	Proximity
Honeywell			
Motion Sensor	1	DT-435T	Dual Technology
Lenel			
Communicator	1	LNL-2220	Network
Interface	4	LNL-1320	Automatic
Life Safety			
Power Supply	1	C8	
Power Supply	1	D8P	
Power Supply	1	FPO150	
Life Safety power			
Power Supply	1	FPO150	Fail Safe
Sentrol			
Door Contact	5	1078C	Magnetic
Universal Battery			
Batteries	2	UB1270k	Sealed Lead Acid

Transitional Living (Independence House) 1723 Fairfax Drive

Building: Transitional Living (Independence House)			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		11
Communicator	Control		1
Intercom	Personnel		2
Interface	Access		3
Power Supply	Control		4
Reader	Access		7
Device or Item	Qty	Model #	Description
Lenel			
Interface	2	LNL-1320	Automatic
Aiphone			
Intercom	1	IX-DA	IP
Intercom	1	IX-MV	IP
Axis Communications			
Camera	5	M3007-PVE	POE
Camera	1	M3707-PVE	POE
Camera	1	P3225-LV	POE
Camera	4	P3225PVE	POE
HID			
Reader	6	920PTPNEK000 FC	Proximity
Lenel			
Communicator	1	LNL-2220	IP
Interface	1	LNL-1320	Automatic
Life Safety			
Power Supply	1	C8	
Power Supply	1	D8P	
Power Supply	1	FPO150	
Linear			
Reader	1	WOR ACP000727	Wiegand
Power Sonic			
Batteries	4	PS 1270	Sealed Lead Acid
Von Duprin			
Power Supply	1	PS914	

Tyrol Hills Park

5101 S 7th Road

Building: TYROL HILLS PARK			
Device or Item	Category		Quantity
Communicator	Control		1
Control Panel	Control		1
Magnetic Lock	Access		2
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Altronix			
Power Supply	1	AL300ULX	
Brivo			
Communicator	1		Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTNNEK00 000	Proximity
Rutherford Controls			
Magnetic Lock	2		Surface

Walter Reed Community Center
2909 S 16th Street

Building: Walter Reed Community Center			
Device or Item	Category		Quantity
Batteries	Control		4
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		18
Interface	Access		3
Keypad	Control		2
Motion Sensor	Alarm		10
Power Supply	Control		2
Device or Item	Qty	Model #	Description
Dmp			
Communicator	1	263LTE	Cellular
Altronix			
Power Supply	1	AL300UL	
Power Supply	1	AL600UL	
Bosch			
Motion Sensor	9	DS835	Dual Technology
Motion Sensor	1	DS970	Dual Technology
DMP			
Control Panel	1	XR150	Security
Interface	1	714-16	Manual
Interface	1	714-4	
Interface	1	714-8	
Keypad	2	7872-W	Security
Sentrol			
Door Contact	18	1076	Magnetic
UltraTech			
Batteries	4	UT-1270	Sealed Lead Acid

WSS Maintenance Warehouse

4202 S 28th Street

Building: WSS MAINTENANCE WAREHOUSE			
Device or Item	Category		Quantity
Batteries	Control		2
Camera	Video		9
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		9
Interface	Access		4
Keypad	Control		2
Module	Control		1
Motion Sensor	Alarm		3
Power Supply	Control		1
Reader	Access		6
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	2	P3807-PVE	POE
Camera	2	P3818-PVE	POE
Bosch			
Motion Sensor	3	DS835	Dual Technology
Dmp			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	2	7872-W	Security
Module	1	714-4	
HID			
Reader	6	920PTPNEK000 FC	Proximity
Lenel			
Interface	3	LNL-1320-S1	
Interface	1	LNL-2220	
Life Safety Power			
Power Supply	1	FPO150	
Pelco			
Camera	1	IM10DN10-1E	POE
Camera	4	IM30DN	POE
Power Sonic			
Batteries	1	PS-1270-F1	Sealed Lead Acid
Sentrol			
Door Contact	6	1078C	Magnetic
Door Contact	3	2707	Magnetic
Universal Battery			
Batteries	1	UB1270	Sealed Lead Acid

WSS Admin

4200 28th S

Building: WSS Admin			
Device or Item	Category		Quantity
Batteries	Control		2
Camera	Video		43
Control Panel	Control		1
Door Contact	Alarm		7
Interface	Access		4
Keypad	Control		2
Motion Sensor	Alarm		2
Power Supply	Control		2
Reader	Access		6
Router	Video		1
Device or Item	Qty	Model #	Description
HID			
Reader	2	910PTPNEK000 FC	Proximity
Reader	4	920PTPNEK000 FC	Proximity
Lenel			
Interface	2	LNL-1320-S3	Automatic
Interface	1	LNL-2220	Automatic
APC			
Power Supply	1	Back-UPS R S 1500	UPS
Axis Communications			
Camera	2	P-3245-LVE	Color
Camera	1	P-3807-PVE	Color
Camera	1	P3225-LVE	Color
Camera	1	P3227-LVE	Color
Camera	1	P3245-LVE	Color
Camera	2	P3719-PLE	
Camera	2	P3807-PVE	Color
Camera	2	P3818-PVE	Color
Bosch			
Motion Sensor	2	DS835	Dual Technology
D-Link			

Fire Station #1

500 S Glebe Road

Building: Fire Station #1			
Device or Item	Category		Quantity
Batteries	Control		2
Interface	Access		2
Power Supply	Control		2
Reader	Access		3
Device or Item	Qty	Model #	Description
APC			
Power Supply	1	Pro 1500	
HID			
Reader	3	920PTPNEK000 FC	Proximity
Lenel			
Interface	1	LNL-1320-S3	Semi-Automatic
Interface	1	LNL-2220	Semi-Automatic
Life Safety power			
Power Supply	1	FPO75	
Power Patrol			
Batteries	2	SLA1075	Sealed Lead Acid

Fire Station #2

4805 Wilson Blvd

Building: Fire Station #2 (includes Safe Haven)				
Device or Item	Category		Quantity	
Camera	Video		1	
Intercom	Personnel		1	
Batteries	Control		4	
Controller	Control		1	
Interface	Access		4	
Reader	Access		9	
Power Supply	Control		2	
Device or Item	Qty	Model #	Description	
Pelco				
Camera	1	IMP219-1	Color	
Talk-A-Phone				
Intercom	1	ETP-400C	Emergency Call	
APC				
Power Supply	1	Pro 1500		
HID				
Reader	9	920PTPNE- K000FC	Proximity	
Lenel				
Interface	4	LNL-1320		
Controller	1	LNL-2220		
Life Safety power				
Power Supply	1	FPO75		
Power Patrol				
Batteries	4	SVA1075	Sealed Lead Acid	

Fire Station # 3

4100 Old Dominion Dr

Building: Fire Station #3 (includes Safe Haven)			
Device or Item	Category		Quantity
Camera	Video		2
Intercom	Personnel		1
Batteries	Control		4
Controller	Control		1
Interface	Access		4
Reader	Access		8
Power Supply	Control		2
Device or Item	Qty	Model #	Description
Pelco			
Camera	2	P3245-LV	Color
Talk-A-Phone			
Intercom	1	ETP-401	Emergency Call
APC			
Power Supply	1	Pro 1500	
HID			
Reader	8	920PTPNE- K000FC	Proximity
Lenel			
Interface	4	LNL-1320	
Controller	1	LNL-2220	
Life Safety power			
Power Supply	1	FPO75	
UltraTech			
Batteries	4	UT 1270	

Fire Station #4

3121 10th St North

Building: Fire Station #4			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		7
Control Panel	Control		1
Intercom	Personnel		2
Interface	Access		4
Power Supply	Control		7
Reader	Access		10
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	4	P3225	POE
Camera	3	P3707	POE
HID			
Reader	1	910PTPNEK000 FC	Proximity
Reader	7	920PTPNEK000 FC	Proximity
APC			
Power Supply	1	Smart UPS 1500	
Aiphone			
Intercom	1	JK-1MED	Video Speaker
Intercom	1	JK-DV	Video Speaker
HID			
Reader	1	910PTPNEK000 FC	Proximity
Reader	1	921PTPNEKOO OFD	Proximity
Lenel			
Control Panel	1	LNL-2220	Access Control
Interface	4	LNL-1320	
Life Safety power			
Power Supply	2	C8	
Power Supply	2	D8P	
Power Supply	2	FPO150	
Ultratech			
Batteries	4	UT 1270	

Fire Station #5

1750 S. Hayes St.

Building: Fire Station #5 (includes Safe Haven)				
Device or Item	Category		Quantity	
Camera	Video		1	
Telephone	Control		2	
Batteries	Control		4	
Intercom	Personnel		1	
Interface	Access		3	
Controller	Control		1	
Power Supply	Control		8	
Reader	Access		8	
Device or Item	Qty	Model #	Description	Install Date
Pelco				
Camera	1	IMP219	Color	
Talk-A-Phone				
Telephone	1	ETP-400C	Emergency Call	
HID				
Reader	6	920TPNEK000FC	Proximity	
Reader	2	920TPNEK000FC	Proximity	
Lenel				
Interface	3	LNL-1320-S3		
Controller	1	LNL-2220		
Life Safety Power				
Power Supply	2	FPO150		
Pelco				
Camera	1	IME219	Color	
Power Sonic				
Batteries	1	PS-1270 F1	Sealed Lead Acid	
Talk-A-Phone				
Intercom	1	ETP-400C		
UltraTech				
Batteries	3	UT-1270	Sealed Lead Acid	
Von Duprin				
Power Supply	1	PS861		
Power Supply	5	PS873		

Fire Station #6

6950 N. Little Falls Road

Building: Fire Station #6			
Device or Item	Category		Quantity
Batteries	Control		3
Camera	Video		1
Client	Control		1
Interface	Access		2
Power Supply	Control		3
Reader	Access		6
Device or Item	Qty	Model #	Description
Life Safety power			
Power Supply	1	C8	
Power Supply	1	P8D	
HID			
Reader	6	920PTPNEK000 FC	Proximity
Lenel			
Client	1	LNL-2220	Network
Interface	2	LNL-1320-S3	Automatic
Life Safety power			
Power Supply	1	FPO150	
Pelco			
Camera	1	IMP219	Color
Universal battery			
Batteries	3	UB1270K	Sealed Lead Acid

Fire Station # 8

4845 Lee Highway

Building: Fire Station # 8			
Device or Item	Category		Quantity
Batteries	Control		4
Interface	Access		6
Main Controller	Control		1
Power Supply	Control		2
Reader	Access		13
Device or Item	Qty	Model #	Description
HID			
Reader	13	921PTPNEK000 FD	Proximity
Lenel			
Interface	6	LNL-1320-S3	
Main Controller	1	LNL-X2220	
Life Safety Power			
Power Supply	1	FPO150	
Power Supply	1	FPO250	
Power Sonic			
Batteries	4	PS-1270 F1	Sealed Lead Acid

Fire Station #9 1900 Walter Reed Dr

Building: Fire Station #9 (includes Safe Haven)			
Device or Item	Category		Quantity
Camera	Video		1
Intercom	Personnel		1
Batteries	Control		4
Controller	Control		1
Interface	Access		4
Reader	Access		8
Power Supply	Control		2
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	1	P3367	
Talk-A-Phone			
Intercom	1	ETP-401	Emergency Call
APC			
Power Supply	1	Pro 1500	
HID			
Reader	8	920PTPNE- K000FC	Proximity
Lenel			
Interface	4	LNL-1320	
Controller	1	LNL-2220	
Altronix			
Power Supply	1	AL600ULPD8CB	
UltraTech			
Batteries	4	UT 1270	

Fire Station #10

1559 Wilson Blvd

Building: Fire Station #10 - 1559 Wilson Blvd			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		7
Communicator	Control		1
Interface	Access		6
Power Supply	Control		2
Reader	Access		14
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	2	M3058-PLVE	POE
Camera	2	P3807-PVE	POE
Camera	1	P3818-PVE	POE
HID			
Reader	14	921PTPNEK000 FD	Proximity
Lenel			
Communicator	1	LNL-X2220	IP
Interface	6	LNL-1320-S3	
Life Safety power			
Power Supply	2	FPO250	
Universal battery			
Batteries	4	UB1270R	Sealed Lead Acid

Fire Training Admin Building

2800 S Taylor Street

Building: Fire Training Admin Building			
Device or Item	Category		Quantity
Batteries	Control		4
Camera	Video		1
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		8
Interface	Access		3
Keypad	Control		2
Motion Sensor	Alarm		2
Power Supply	Control		3
Reader	Access		5
Device or Item	Qty	Model #	Description
HID			
Reader	5	920PTPNEK000 FC	Proximity
APC			
Power Supply	1	Back-UPS Pro 1500	UPS
Axis Communications			
Camera	1	Q6000-MkII	POE
Bosch			
Control Panel	1	D7412G	Security
Interface	1	D8128D	Zone Expander
Keypad	2	D1260	Security
Motion Sensor	2	DS835i	Dual Technology
Lenel			
Communicator	1	LNL-2220	Network
Interface	2	LNL-1320-S3	Automatic
Life Safety			
Power Supply	1	FPO150	
Power Supply	1	FPO75	
Sentrol			
Door Contact	1	1077	Plunger
Door Contact	7	1078C	Magnetic
Universal Battery			
Batteries	1	UB 1270	Sealed Lead Acid
Universal battery			
Batteries	1	UB 1270	Sealed Lead Acid
Batteries	2	UB1270	Sealed Lead Acid

Dept of Parks and Recreation Building
2700 S Taylor St

Building: Parks Ops Center			
Device or Item	Category		Quantity
Batteries	Control		13
Camera	Video		21
Communicator	Control		1
Control Panel	Control		2
Controller	Video		1
DVR	Video		1
Door Contact	Alarm		33
Interface	Access		1
Keypad	Control		13
Motion Sensor	Alarm		18
Multiplexer	Video		1
Power Supply	Control		15
Router	Video		1
Video Monitor	Video		1
Device or Item	Qty	Model #	Description
APC			
Power Supply	1	Smart-UPS 2200	
Altronix			
Power Supply	1	AL100ULB	
Power Supply	10	AL201ULB	
Power Supply	2	WPTV248300U L	
Bosch			
Control Panel	2	D9412G	Security
Keypad	13	D1260	Security
Motion Sensor	18	DS835	Dual Technology
Dell			
Video Monitor	1	17"	Color-LCD
Lenel			
Communicator	1	LNL-2220	
Interface	1	LNL-1320	Automatic
Life Safety power			
Power Supply	1	FPO75	
Nitek			
Multiplexer	1	VH1639	Video Hub
Panasonic			
Camera	15	Analog Color	Analog Color
Pelco			
Camera	1	Analog Color	Color
Camera	1	IM10LW1-1E	Color

Camera	2	IM10LW10-1E	Color
Camera	2	IMSOLW10	Color
Controller	1	ENC5416	Encoder
DVR	1	DS SRV	Time Lapse
Power Sonic			
Batteries	2	1270	Sealed Lead Acid
Sentrol			
Door Contact	27	1076	Magnetic
Door Contact	6	176	Magnetic
Trendnet			
Router	1	TPE-1020WS	Digital
UltraTech			
Batteries	11	UT-1270	Sealed Lead Acid

Lubber Run Community Center

300 N Park Drive

Building: Lubber Run Community Center			
Device or Item	Category		Quantity
Batteries	Control		2
Control Panel	Control		1
Reader	Access		28
Door Contact	Alarm		2
Interface	Access		1
Keypad	Control		1
Motion Sensor	Alarm		8
Device or Item	Qty	Model #	Description
Ademco			
Door Contact	1	7939	Magnetic
Bosch			
Control Panel	1	D9412GV3	Security
Interface	1	D8125	Automatic
Keypad	1	D1260	Security
Motion Sensor	8	DS775RF	Dual Technology
Sentrol			
Door Contact	1	1076	Magnetic
UltraTech			
Batteries	2	UT-1270	Sealed Lead Acid

Argus House

1527 Clarendon Blvd

Building: Argus House			
Device or Item	Category		Quantity
Batteries	Control		1
Camera	Video		18
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		5
Keypad	Control		2
Device or Item	Qty	Model #	Description
Axis Communications			
Camera	1		Color
Camera	2	M3058-PLVE	Color
Camera	1	P3265-VE	Color
DMP			
Communicator	1	263LTE	Cellular
Control Panel	1	XR150	Security
Keypad	1	7872-W	
Keypad	1	7872-W	Security
Pelco			
Camera	1	IM10C10	Color
Camera	1	IMPS110-1	Color
Camera	10	IMSOC10	Color
Camera	2	IMSOLW10-1E	Color
Sentrol			
Door Contact	5	1076	Magnetic
UltraTech			
Batteries	1	UT-1270	Sealed Lead Acid

Kenmore Middle School

200 S Carlin Springs

Building: Kenmore Middle School 200 S Carlin Springs Rd.			
Device or Item	Category		Quantity
Communicator	Control		1
Control Panel	Control		1
Magnetic Lock	Access		2
Power Supply	Control		1
Reader	Access		2
Device or Item	Qty	Model #	Description
Altronix			
Power Supply	1	AL300ULX	Fail Safe
Brivo			
Communicator	1	B-OA-CNM1-Z 1	Cellular
Control Panel	1	ACS300	Access Control
HID			
Reader	2	920PTPNEK00FC	Proximity
Securiton			
Magnetic Lock	2	M680EBDX	Surface

Detention Center
1425 N Courthouse Road

Building: Detention Center			
Device or Item	Category		Quantity
Fire Panel	Fire Alarm		1

Head Start
2920 S Glebe Road

Building: Head Start 2920 S GLEBE RD		
Device or Item	Category	Quantity
Fire Panel	Telecom Fire Alarm	1

Woodmont Center

2422 North Filmore Street

Building: Woodmont Center			
Device or Item	Category		Quantity
Batteries	Control		6
Communicator	Control		1
Control Panel	Control		2
Door Contact	Alarm		7
Interface	Access		4
Keypad	Control		5
Motion Sensor	Alarm		14
Power Supply	Control		4
Reader	Access		1
Device or Item	Qty	Model #	Description
Door Contact	1		
Bosch			
Interface	1	D8125	
Interface	1	D8128	
Motion Sensor	6	DS8351	Dual Technology
Motion Sensor	1	DS930	Dual Technology
Motion Sensor	5	INS-AP	Dual Technology
Motion Sensor	2	ISC-BDL2-W12	Dual Technology
DMP			
Communicator	1	263LTE	Cellular
Control Panel	2	XR150	Security
Interface	2	736P	
Keypad	5	7872-W	Security
ESD			
Power Supply	1	SPS-5	
HID			
Reader	1	920PTPNEK000 FC	Proximity
Life Safety Power			
Power Supply	1	C8	
Power Supply	1	D8P	
Power Supply	1	FPO75	
Power Sonic			
Batteries	4	PS-1270	Sealed Lead Acid
Sentrol			
Camera	5	P3225-LVE	POE

Westover Library

1644 McKinley Road

Building: Westover Library			
Device or Item	Category		Quantity
Batteries	Control		4
Button	Alarm		1
Camera	Video		7
Communicator	Control		1
Control Panel	Control		1
Door Contact	Alarm		5
Interface	Access		2
Keypad	Control		3
Module	Control		2
Motion Sensor	Alarm		16
Power Supply	Control		5
Reader	Access		6
Sensor	Alarm		2
Device or Item	Qty	Model #	Description
DMP			
Module	1	736P	
Ultratech			
Batteries	1	UT-1270	Sealed Lead Acid
Universal battery			
Batteries	2	UB1270	Sealed Lead Acid
Sensor			
Sensor	2	Waterbug	Environmental
Axis Communications			
Camera	1	M3058-PLVE	POE
Camera	2	P3245-LVE	POE
Bosch			
Motion Sensor	15	DS835i	Dual Technology
Motion Sensor	1	DS970	Dual Technology
DMP			
Control Panel	1	XR150	Security
Keypad	1	7278-W	Security
Keypad	2	7872-W	Security
Hid			
Reader	2	910PTPNEK000 FC	Proximity
Reader	4	920PTPNEK000 FC	Proximity
Lenel			
Communicator	1	LNL-2220	IP
Interface	2	LNL-1320	
Module	1	LNL-1320-S3	Group Control

Life Safety Power			
Power Supply	1	D8P	Fail Safe
Power Supply	1	FPO150	Fail Safe
Life Safety Power			
Power Supply	1	8100	
Power Supply	1	C8	
Power Supply	1	FPO150	
Linear			
Button	1	D67F	
Pelco			
Camera	4	IMP321	POE
Sentrol			
Door Contact	5	1076	Magnetic
Universal battery			
Batteries	1	UB1270	Sealed Lead Acid

TE & O Warehouse
4280 29TH South

Building: TE & O Warehouse			
Device or Item	Category		Quantity
Fire Panel	N/A		1

Courts Police Building
1425 N Courthouse Road

Building: Courts Police Building			
Device or Item	Category		Quantity
Fire Panel		N/A	1

Shirlington Bus Station

2975 S Quincy St

Building: SHIRLINGTON BUS STATION			
Device or Item	Category		Quantity
Batteries	Control		6
Button	Alarm		1
Camera	Video		10
Console	Control		2
Control Panel	Control		1
Door Contact	Alarm		3
Intercom	Personnel		3
Keypad	Control		1
Power Supply	Control		6
Reader	Access		3
Device or Item	Qty	Model #	Description
APC			
Power Supply	1	Back-UPS Pro 1500	UPS
Altronix			
Power Supply	1	ALTV2417ULCB X	
Axis Communications			
Camera	9	P3225	Color
Camera	1	P3707	Color
DMP			
Control Panel	1	XR150	Security
Keypad	1	7872-W	Security
HID			
Reader	3	920PTPNEK000 FC	Proximity
Honeywell			
Power Supply	1	HP312CX	
Lenel			
Console	1	LNL-1320-S3	
Console	1	LNL-2220	Access Control
Lifesafety			
Power Supply	1	C8	
Power Supply	1	D8F	
Power Supply	1	FPO150	
Power Sonic			
Batteries	1	PS-1280-F1	Sealed Lead Acid

Security Controls			
Button	1	HUB2SA	Hold-Up
Sentrol			
Door Contact	3	1078C	Magnetic
Talk-A-Phone			
Intercom	3	ETP 400C	Emergency Call
Ultratech			
Batteries	1	UT 1270	Sealed Lead Acid
Batteries	2	UT-1270	
Universal battery			
Batteries	2	UB1270	Sealed Lead Acid

Emergency Radio Sites

Building: Emergency Radio Sites			
Locations	Address		Quantity
Ballston Tower	901 N Pollard St		1
BB&T	6400 Arlington Blvd		1
CHP	2300 Clarendon Blvd		1
Shirlington	2900 S Quincy St		1
Ritz-Carlton	1200 S Hayes St		1
Device or Item	Qty	Model #	Description
Lenel			
Reader/Controller	5	LNL-X2210	

SCHEDULE B - SOFTWARE

LOCATION	QTY	SYSTEM	MANUFACTURER &M/N	CURRENT VERSION INSTALLED
VARIOUS	51	EAC	LENEL ONGUARD	<ul style="list-style-type: none">• 8.2
VARIOUS	8	EAC	BRIVO	<ul style="list-style-type: none">• ACS300
VARIOUS		CCTV	MILESTONE XPROTECT	<ul style="list-style-type: none">• Corporate 2022 R3
VARIOUS		CCTV	BRIEFCAM INSIGHTS	<ul style="list-style-type: none">• 6.0• Milestone Add-On

SCHEDULE C - Guidelines

EQUIPMENT PREVENTIVE MAINTENANCE, INSPECTION, AND TESTING GUIDELINES

At a minimum, the Contractor shall provide all necessary personnel, transportation, parking fees, tools-of-the-trade including specialized diagnostic testing equipment and consumable supplies to perform maintenance tasks requirements identified below for all equipment indicated in Schedule A and Schedule B. County personnel will not be available to assist the Contractor.

Any deviations from the requirements below require the advance approval of the County Project Officer. This list is not represented as being all-inclusive of the services to be performed or the frequency required. The Contractor shall be required to perform all services necessary to provide a safe and efficient maintenance program commensurate with recommended practices as specified by each manufacturer.

The following applies to all equipment indicated in Schedule A and Schedule B:

During annual visits, the Contractor shall also perform all semi-annually, quarterly, monthly, weekly, and daily tasks in addition to the annual task items. During semi-annual visits, the Contractor shall also perform all quarterly, monthly, weekly, and daily tasks in addition to the semi-annually task items. During quarterly visits, the Contractor shall also perform all monthly, weekly, and daily tasks in addition to the quarterly task items. During monthly visits, the Contractor shall also perform weekly and daily tasks in addition to the monthly tasks.

1. ACCESS CONTROL SYSTEM

1.1. Controller

1.1.1. Annually

- 1.1.1.1. Perform visual inspection and check for proper operation.
- 1.1.1.2. Clean and remove debris/dust per manufacturer approved method.
- 1.1.1.3. Check and record input/output voltage.

1.2. IOU units, Elevator modules, etc.

1.2.1. Annually

- 1.2.1.1. Perform visual inspection and check for proper operation.
- 1.2.1.2. Clean and remove debris/dust per manufacturer approved method.
- 1.2.1.3. Check and record voltage.

1.3. Card Reader

1.3.1. Annually

- 1.3.1.1. Perform visual inspection and check for proper operation.
- 1.3.1.2. Clean and remove debris/dust per manufacturer approved method.

1.4. Door Power Supply

1.4.1. Annually

- 1.4.1.1. Perform visual inspection and check for proper operation.
- 1.4.1.2. Clean and remove debris/dust per manufacturer approved method.
- 1.4.1.3. Check and record input/output voltage.

SCHEDULE C - Guidelines

1.5. Workstation

1.5.1. Annually

1.5.1.1. Perform visual inspection and check for proper operation.

1.5.1.2. Clean and remove debris/dust per manufacturer approved method.

1.5.1.3. Back-up all log files and maintain a copy of the back-up offsite. Provide a copy of the back-up to the County Project Officer.

1.6. Intercoms

1.6.1. Annually

1.6.1.1. Perform visual inspection and check for proper operation.

1.6.1.2. Clean and remove debris/dust per manufacturer approved method.

2. HARDWARE SYSTEM

2.1. Electric Locking Hardware

2.1.1. Annually

2.1.1.1. Inspect and test for proper attachment and voltage in conjunction with Card Reader inspections. Adjust as necessary to provide proper operation.

3. UNINTERRUPTABLE POWER SUPPLY SYSTEM

3.1. Battery UPS

3.1.1. Annually

3.1.1.1. Perform visual inspection and check for proper operation.

3.1.1.2. Clean and remove debris/dust per manufacturer approved method.

3.1.1.3. Pull logs using manufacturer software, compile report and make unit and/or battery replacement recommendations to County Project Officer.

4. VIDEO SURVEILLANCE SYSTEM

4.1. Analog Cameras

4.1.1. Annually

4.1.1.1. Perform visual inspection and check for proper operation.

4.1.1.2. Clean and remove debris/dust per manufacturer approved method.

4.1.1.3. Adjust focus, as necessary.

4.1.1.4. Check time stamp and adjust for accuracy.

4.2. DVRs

4.2.1. Annually

4.2.1.1. Perform visual inspection and check for proper operation.

4.2.1.2. Clean and remove debris/dust per manufacturer approved method.

4.2.1.3. Check for proper recording and operation.

SCHEDULE C - Guidelines

4.3. Camera Power Supply

4.3.1. Annually

- 4.3.1.1. Perform visual inspection and check for proper operation.
- 4.3.1.2. Clean and remove debris/dust per manufacturer approved method.
- 4.3.1.3. Check and record input/output voltage.

4.4. Video Client Station

4.4.1. Annually

- 4.4.1.1. Perform visual inspection and check for proper operation.
- 4.4.1.2. Clean and remove debris/dust per manufacturer approved method.
- 4.4.1.3. Check for proper network connection.

4.5. Server/Server Base/Server Expander/Ethernet Switch

4.5.1. Annually

- 4.5.1.1. Perform visual inspection and check for proper operation.
- 4.5.1.2. Clean and remove debris/dust per manufacturer approved method.
- 4.5.1.3. Check for proper recording and operation.

4.6. IP Cameras

4.6.1. Annually

- 4.6.1.1. Perform visual inspection and check for proper operation.
- 4.6.1.2. Clean and remove debris/dust per manufacturer approved method.
- 4.6.1.3. Check time stamp and adjust for accuracy.

5. SOFTWARE AND FIRMWARE LISTED IN SCHEDULE B

5.1. Annually

- 5.1.1. Check for software and firmware updates. Submit a report to the County Project Officer or designee indicating whether there are any software and firmware updates available that would enhance the systems within fifteen (15) calendar days.
- 5.1.2. The report shall include all equipment listed in Schedule B, current software/firmware version, a cost for the updates and the Contractor's recommendation on whether the updates are necessary.

6. SAFE HAVENS

6.1.1. Monthly

- 6.1.1.1. Test all equipment for proper operation/securing of site on activation.
- 6.1.1.2. Confirm signal transmission and verify data with Arlington County Emergency Communications Center.
- 6.1.1.3. Document results/recommendations and send to project officer within 72 hours.

6.1.2. Quarterly

- 6.1.2.1. Perform items listed as in section 1.2 for IOU units.
- 6.1.2.2. Perform items listed as in section 1.4 for door power supply.
- 6.1.2.3. Perform items listed as in section 1.6 for intercom.
- 6.1.2.4. Perform items listed as in section 2 for electric locking hardware.
- 6.1.2.5. Perform items listed as in section 3 for UPS.
- 6.1.2.6. Perform items listed as in section 4 for CCTV.

SCHEDULE C - Guidelines

7. PERIMETER GATES

7.1.1. Monthly

7.1.1.1. Perform general visual inspection.

7.1.1.2. Confirm proper operation of electronic access control system.