Michael A. Register, P.E., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940 • www.sjrwmd.com

DATE: January 5, 2022

TO: Prospective Respondents

FROM: Amy Lucey, Procurement Specialist

SUBJECT: Addendum #2 to Invitation For Bid, # 37489, Refurbish/Upgrade the Unit 2 Pump Station

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1. Could you please confirm the service will be 1200A?

A1: The size of the new service shall be a 1,000 amp service. Please refer to Addendum 1.

Q2: During the site visit, we saw a sample installation, and I don't recall seeing a Power Monitor?

A2: Yes, Power Monitors are required for this project.

Q3: If you need the power monitor, do you accept other manufacturers?

A3: Yes, other manufacturers are acceptable.

Q4: Can you share the existing mechanical drawings?

A4: There are no mechanical drawings pertaining to this project. The commodity code was selected in error on the VBS system.

NOTE: The Proposal Due Date remains 2:00 p.m., Thursday, January 13, 2022.

Please acknowledge receipt of this Addendum on the Bid FORM provided in the proposal package.

If you have any questions, please e-mail me at <u>alucey@sjrwmd.com</u>.