



Board of County Commissioners • Escambia County, Florida

Office of Purchasing

Date: February 25, 2022
To: All Known Prospective Bidders
RE: PD 21-22.024 Pine Valley Estates (Phase 1 & 2)
Addendum 1
Solicitation Identification Number PD 21-22.024

This notice is to provide for Acknowledgement of Addendum 1.

1. Responses to questions received are provided below. Responses are in red.

Regarding the Pine Valley project will the engineer accept FDOT polypropylene pipe as an equal to the RCP pipe? There is also slotted RCP pipe on the project. Will the engineer accept FDOT perforated polypropylene pipe as an equal?

FDOT polypropylene pipe is acceptable; except where it is located below roadway pavement, RCP is required.

This Addendum Number 1 is furnished to all known prospective Bidders. Please sign and return one copy of this Addendum, with original signature, with your bid as an acknowledgement of you having received same. You may photocopy for your record

Sincerely,

Charlie Maholan
Purchasing Coordinator

Acknowledgement of Receipt of Addendum 1:

SIGNED: _____

COMPANY: _____