

---

## ADDENDUM

**Posted Date:** March 1, 2024

**Solicitation No.:** 24-53

**Solicitation Name:** Eaton UPS/PDU

**Subject:** Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced solicitation. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases, or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded phrases or sentences represent additions to the original solicitation.

### 1. QUESTIONS/ANSWERS

1.	Do you plan on using external battery packs with the 1500 VA units?
<b>Answer</b>	<b>No</b>
2.	Do you Require double conversion online units?
<b>Answer</b>	<b>Yes</b>
3.	Will the install take place during normal business hours, or should we plan for nights/weekends?
<b>Answer</b>	<b>This is for the purchase of the product only, no installs by others</b>
4.	Is page 21 of the RFP required to be notarized in TN?
<b>Answer</b>	<b>No, you can cross out Tennessee and put the notarizing state's name in its place</b>

---

**BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.**

**ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.**

*Steven Hodgen*

---

Steven Hodgen  
Purchasing Supervisor