



**ITB #2019-007 CONCRETE SIDEWALK AND RAMP REPAIR
QUESTIONS & ANSWERS
CLARIFICATION ON SPECIFICATIONS
ADDENDUM 1**

Return to: Lumpkin County Board of Commissioners
Ryan McDuffie, Purchasing Agent
99 Courthouse Hill, Suite D
Dahlonega, GA 30533

Bid Closing Date: August 23, 2019 at 2:00 PM, EST
Bid Issue Date: July 24, 2019
Addendum Issue Date: August 19, 2019 at 5:00 PM, EST
Pages: 1
By: Ryan McDuffie, Purchasing Agent

Vendor Name: _____
(A copy must be attached to the Addenda Acknowledgement)

QUESTIONS

1. What type of concrete would the County like to be used?
 - a. DOT Class A concrete.
2. Who will be demoing the shrubbery at the Mental Health building?
 - a. The County will demo the shrubbery.
3. What is the finish on the handrails?
 - a. The handrails will be painted.