



**TOWN OF SUMMERVILLE PARKS & RECREATION DEPARTMENT**

*"Creating Sense of Place Through Parks & Play"*

---

**TO:** All Bidders

**FROM:** Amy Evans, Parks & Recreation Director

**DATE:** 7/13/2021

**RE:** Addendum #1 to Wassamassaw Park Trail Resurfacing

---

Addendum #1 - Answers to Questions Received Regarding Project

1. Where will [we] be able to unload and stage equipment and material?

Answer: There is a parking lot at the front of the park that can be used for this purpose. However, it is not a secure area overnight.

2. The Surface Type C thickness of 225lbs/SY is too much to be placed in one lift per the SCDOT. The limit would be 2" of Surface which is **220lbs/SY**. What would you like to use for this?

Answer: We believe that 225lbs/SY is appropriate. However, if you believe 220lbs/SY is correct, please note this on your submittal as an exception to specifications with an explanation of why as outlined in the bid documents. The 2" depth must be met.

3. The Bid Invitation states that the project will be awarded in a lump sum basis, but then we are giving unit prices. Will it be a lump sum job or a unit price job?

Answer: Please provide unit prices, but the job will be awarded based on the lump sum.