

Drawings and Specifications For

RENOVATIONS AND UPGRADES OF AN EXISTING UNINTERRUPTIBLE POWER SYSTEM & EQUIPMENT FOR THE CITY OF LAGRANGE, LAGRANGE TECHNOLOGY CENTER, LAGRANGE, GEORGIA, JOB NO. 15003

Bidders are notified that the above Project Drawings and Specifications are modified as set forth below. All other provisions of the Specifications, Drawings, and other Contract Documents previously issued remain unchanged.

THE FOLLOWING CLARIFICATIONS ARE ISSUED FOR THE PROJECT AT THIS TIME.

QUESTIONS AND RESPONSES

1. In the pre-bid meeting on July 1, 2015 it was discussed that the Owner would like to monitor the new UPS along with some (other) existing Eaton equipment through a server based software. Is it the intent that the software be provided as a part of the UPS package in this project? If so, please define the software that is to be supplied.

The Owner's intent is to obtain the monitoring software from the UPS Manufacturer. The software should be cable of supporting between 1 and 10 IP addresses and shall be compatible with the new UPS furnished as a part of this Project. Any cost for the software shall be included with the cost of the equipment furnished as a part of this Project. The software shall be furnished to the Owner for Owner installation on their network.

2. Is there a liquidated damages clause in this contract?

There is no liquidated damages clause that shall be required for this contract.

3. Is there a completion date set or do they (the Contractor) just need to specify?

The completion date will be set by the Bidder and a number of consecutive days to complete is required as a part of the Bid Form at the top of page BF-2. In addition, this shall be a part of the Schedule as noted on Page 1A-2, 07 SEQUENCE OF OPERATIONS and Page 1B-1, 03 SEQUENCE OF SCHEDULING.

4. The distribution cabinet specified to be supplied with the UPS does not indicate (it) to be grounded to the grounding electrode system. Should this cabinet be grounded? If so, please define as to the size requirements and the location it is to be grounded.

Yes, the UPS equipment transformer requires a ground that shall be run to a connection point with the electrical grounding system per the National Electrical Code. This ground wire size shall be #1/0.

THERE ARE NO CHANGES MADE TO THE SPECIFICATIONS AT THIS TIME.

THERE ARE NO CHANGES MADE TO THE DRAWINGS AT THIS TIME.

END OF ADDENDUM NO. 1

L. LEIGH MORGAN, JR.  
CONSULTING ENGINEER  
SENOIA, GEORGIA