

City of Tallmadge
Department of Public Service
2021 East Avenue/Washburn Road Intersection Improvements

Addendum No. 3 to Bidding Documents – June 3, 2021

This addendum is for questions that have been asked about the Bid. All answers to the questions are in red font.

1. 611 Type- B Trench Pavement Restoration:- Plan note “Pavement Restoration for Pipe Installation” on plan sheet 7/88 calls for all trenches to be constructed per ODOT 611 and in addition calls for LSM backfill for the trenches only within ZOI outside the pavement. But the typical on the same page calls for LSM back fill for trenches under pavement too. Please confirm if the trenches under pavement can be backfilled with ODOT #304 or #57 to bottom of subgrade.

2. 611 Type- B Backfill for Trenches in 1:1 ZOI :- Plan note ‘Pavement Restoration for Pipe Installation” mentioned above calls for LSM backfill for trenches under ZOI, but the plan notes on plan sheet 82/88 for Sanitary Forcemain call for ODOT #304 stone in trenches under ZOI. Please confirm if ODOT #304 can also be used for 611 Type-B conduit trenches in ZOI similar to Sanitary Foremain.

All trenches within the ZOI or under pavement shall be back filled with LSM.

I acknowledge the receipt of Addendum No. 3:

Company Name

Officer's Name

Officer's Signature

Date

THIS COMPLETED FORM MUST BE SUBMITTED WITH BID PROPOSAL