



OFFICE OF PROCUREMENT SERVICES
335 FOUR MILE ROAD
CONWAY, SC 29526-6005

AMENDMENT No. # 1

Posting Date: Tuesday, February 7, 2023

Solicitation Number: **2223-31AR**

Description: **Roof Access Safety System**

AMENDMENTS TO SOLICITATION: (a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: <https://vrapp.vendorregistry.com/Bids/View/BidsList?BuyerId=2f302e8a-69b0-407b-a21a-3368d004365e> (b) Offerors shall acknowledge receipt of any amendment to this solicitation (1) by signing and returning the amendment, (2) by letter, or (3) by submitting a bid that indicates in some way that the bidder received the amendment. (c) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged. [02-2A005-1]

QUESTIONS FROM OFFERORS - AMENDMENT (JUN 2017): The solicitation is amended as provided herein. Information or changes resulting from questions will be shown in a question-and-answer format. All questions received have been reprinted below. The "District's Response" should be read without reference to the questions. The questions are included solely to provide a cross-reference to the potential offeror that submitted the question. Questions do not form a part of the contract. The "District's Response" does. Any restatement of part or all of an existing provision of the solicitation in an answer does not modify the original provision except as follows: underline text is added to the original provision. Stricken text is deleted. [02-2A097-1]

SUBMIT OFFER BY (OPENING DATE) AND TIME REMAINS THE SAME.

Q1: Need confirm if we should provide a proposal for the ladders in this submittal?

A1: Specifications have been revised to read as follows:

Section III.SCOPE OF WORK, MINIMUM REQUIREMENTS: The system will be bolted on easily to a standard fixed OSHA approved ladder **provided by the District. Specifications do not require vendor to provide the ladder.**

- Bolt on system that easily attaches to OSHA standard fixed ladder **provided by the District.**

Q2: I wanted to make you aware that pursuant to the new OSHA standards that has rolled out, it will be required that you have safety guardrails around each hatch door opening to prevent workers from falling into the open hole when the hatch door is open. Would you want a proposal for this in the proposal as well?

A2: No. No change to specifications.