



SOLICITATION ADDENDUM

City of Leesburg | Purchasing Division
204 N. 5th Street | PO Box 4906030
Leesburg, FL 34749-6030
Phone: (352) 728-9880 | purch@leesburgflorida.gov

ADDENDUM NO. 2

Date Issued: March 26, 2018

Solicitation: **180131 – Chlorine Scrubber Rehabilitation**

The following changes, revisions, additions and information are made to solicitation document **180131**. Bidders shall take all information into account when preparing their bid response.

Language removed from the specifications is shown as ~~struckthrough~~. Language that is added or inserted shown as ***bold, italic and underlined***.

REVISION TO SCHEDULE OF BID ITEMS

This Addendum provides a revised Schedule of Bid Items form that must be used in place of the original form when submitting your bid.

ADDITIONAL INFORMATION

The Sewer Use Regulations (aka Industrial Pre-Treatment Plan) document following this link is made part of this solicitation:

https://library.municode.com/fl/leesburg/codes/code_of_ordinances?nodeId=PTIICOO R CH22UT ARTIISE DIV5SEUSRE

QUESTIONS AND ANSWERS

The following are answers to all questions received to date. Information shall be considered by proposers when preparing their responses. Questions 1 through 3 answered in Addendum No.1.

- Q4. Can we get the information on water quality requirements for disposal of spent acid and spent water rinse solution into plant drain system?
A4. *Refer to Sewer Usage Regulations.*
- Q5. Confirming the 15 day completion time will begin from the time the scrubber work is started and system is taken off line?
A5. *Yes*
- Q6. City wants fan frame replacement cost, drain line PVC pipe and fitting replacement cost, and site level PVC pipe and fittings replacement cost included in bid price?
A6. *As per Addendum No.2, A Bid Item No.2 has been added for the replacement of exterior components.*

All other elements of the Solicitation Document remain unchanged.

Please direct any questions related to this addendum to the Purchasing Office.

ACKNOWLEDGEMENT

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response in the space provided on the Certification/Addendum Acknowledgement Form included in the original solicitation document. Failure to do so may subject the bidder to disqualification.

IFB 180131

****** REVISED – ADDENDUM NO. 2 ******

SCHEDULE OF BID ITEMS

Your Bid MUST BE submitted on this form. Double check the Bid prices.
 Amounts cannot be changed following the Bid due date and time.

Submitting Vendor Name: _____

BASE BID

ITEM NO.	ITEM DESCRIPTION	QTY	UNIT	<u>BID PRICE</u>
1	REHABILITATION OF A CHLORINE SCRUBBER as specified in the bid documents.	1	LS	\$
2	<i>REPLACEMENT OF EXTERNAL COMPONENTS to include exterior PVC piping, blower motor and squirrel cage assembly to include the housing/cover.</i>	1	LS	\$
TOTAL BASE BID:				\$

ADDITIVE ALTERNATE

Provide a unit pricing on the following additive alternative item. The unit price entered here will be added or deducted should the City select to use this option for disposal.

ITEM NO.	ITEM DESCRIPTION	QTY	UNIT	BID PRICE
AA.1	DISPOSE OF CAUSTIC SOLUTION ON SITE. Solution must be neutralized to the level approved by the City and disposed of into the plant.	1	LS	\$ [] Deductive Price [] Additive Price

Time for Completion

Completion of project is desired within **FIFTEEN (15) CALENDAR DAYS** from Notice to Proceed (NTP). Bids which do not indicate a completion time that is within this delivery time may be deemed as non-responsive.

Number of CALENDAR DAYS to begin work after receipt of NTP: _____ Calendar Days

Number of CALENDAR DAYS to completion after receipt of NTP: _____ Calendar Days