



SOLICITATION ADDENDUM

City of Leesburg | Purchasing Division
204 N. 5th Street | PO Box 4906030
Leesburg, FL 34749-6030
Phone: (352) 728-9880 | purch@leesburgflorida.gov

ADDENDUM NO. 1

Date Issued: March 20, 2018

Solicitation: **180131 – Chlorine Scrubber Rehabilitation**

The following changes, revisions, additions and information are made to solicitation document **180131**. Bidders shall take all information into account when preparing their bid response.

Language removed from the specifications is shown as ~~strikethrough~~. Language that is added or inserted shown as ***bold, italic and underlined***.

REVISION TO SCHEDULE OF BID ITEMS

This Addendum provides a revised Schedule of Bid Items form and must be used in place of the original form when submitting your bid. Two additive items have been added

QUESTIONS AND ANSWERS

The following are answers to all questions received to date. Information shall be considered by proposers when preparing their responses.

- Q1. When was the last time The City of Leesburg's chlorine scrubber was acid washed/cleaned? Is there information on how much solids buildup or how much muriatic acid was used to clean the system during the last service?
- A1. *The last time the unit was cleaned was June 20, 2011. Detailed information on last service is not available.*
- Q2. We see that the caustic needs to be disposed of off-site at a disposal facility. Does this apply to the water needed to flush the system in SW-3.5 and the muriatic acid solution produced in SW-3.8 as well? Or can these solutions be neutralized as needed and drained to the plant drain?
- A2. *See Addendum No.1 for a revised Item Bid Schedule to reflect an Additive Alternate for on-site disposal. The City shall decide the method of disposal.*
- Q3. Do all the steps in the technical specifications need to be strictly adhered? Our standard process does not involve filling up the scrubber repeatedly with water for flushing (Steps SW-3.7 and SW-3.10). Instead we thoroughly rinse and water flush the system manually using a hose in order to limit the amount of wastewater that is generated.
- A3. *No. Contractor must follow the steps as specified in the Owner's Manual.*

All other elements of the Solicitation Document remain unchanged.

Please direct any questions related to this addendum to the Purchasing Office.

ACKNOWLEDGEMENT

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response in the space provided on the Certification/Addendum Acknowledgement Form included in the original solicitation document. Failure to do so may subject the bidder to disqualification.

IFB 180131

****** REVISED – ADDENDUM NO. 1 ******

SCHEDULE OF BID ITEMS

Your Bid MUST BE submitted on this form. Double check the Bid prices.
 Amounts cannot be changed following the Bid due date and time.

Submitting Vendor Name: _____

BASE BID

ITEM NO.	ITEM DESCRIPTION	QTY	UNIT	<u>BID PRICE</u>
1	REHABILITATION OF A CHLORINE SCRUBBER as specified in the bid documents.	1	LS	\$
TOTAL BASE BID:				\$

ADDITIVE ALTERNATE

Provide a unit pricing on the following additive alternative item. The unit price entered here will be added or deducted should the City select to use this option for disposal.

<u>ITEM NO.</u>	<u>ITEM DESCRIPTION</u>	<u>QTY</u>	<u>UNIT</u>	<u>BID PRICE</u>
<u>AA.1</u>	<u>DISPOSE OF CAUSTIC SOLUTION ON SITE. Solution must be neutralized to the level approved by the City and disposed of into the plant.</u>	<u>1</u>	<u>LS</u>	\$ [] Deductive Price [] Additive Price

Time for Completion

Completion of project is desired within **FIFTEEN (15) CALENDAR DAYS** from Notice to Proceed (NTP). Bids which do not indicate a completion time that is within this delivery time may be deemed as non-responsive.

Number of CALENDAR DAYS to <u>begin</u> work after receipt of NTP:	_____ Calendar Days
Number of CALENDAR DAYS to <u>completion</u> after receipt of NTP:	_____ Calendar Days