

**ADDENDUM NO. 2**

**DATE:** January 3, 2022  
**TO:** All Potential Proposers  
**FROM:** Taylor Childress, Procurement Specialist, City of Knoxville  
**SUBJECT:** Addendum No. 2 to ITB- Bollards

**PROPOSALS TO BE OPENED:** \*\*January 7, 2022 11:00 AM (Eastern Time)

This addendum is being published to provide clarification regarding the above referenced invitation to bid. This addendum becomes a part of the contract documents and modifies the original specifications as follows:

Items for Clarification:

**PROPOSALS TO BE OPENED:** \*\*January 7, 2022 11:00 AM (Eastern Time)

**Question:** Please confirm steel . On technical specification page you request schedule 80 and on the question answer page schedule 40.

**Response:** Bollards should be schedule 80. An error was posted in addendum 1.

**END OF ADDENDUM NO. 2**