

ADDENDUM NO. III

BID NUMBER: 305960

BID TITLE: Liquid Calcium Nitrate

DEPARTMENT: Waste Resources Division, Public Works

DATE OF ADDENDUM: August 18, 2020

BID DUE DATE: August 26, 2020

BID DUE TIME: 2:00 p.m., e.s.t.

REASON: ANSWERS TO QUESTIONS

Q. This question is in reference to Addendum II from 8-12-20 and I have highlighted the verbiage I would like further information on. The City of Chattanooga's priority is to maintain less than 10ppm at the discharge point of all feed sites

A. Our goal is to feed enough calcium nitrate so that there is a residual of less than 10ppm and not a significant amount of nitrates leftover so that we are not over feeding.

Q. The volume stated for Calcium Nitrate is equal to over 171 tank truckloads per year, at 3600 gals per shipment. Can you confirm this volume is accurate?

A. Tank loads will vary from year to year. We cannot guarantee any number of truck loads. In addition, we expect that not all loads will be 3600 gallons. The vendor may choose to use smaller trucks to make access to some locations easier. Some of the loads are split loads which indicate that part of the load will go to one site and the rest will go to one or more additional sites.

Q. Would you be able to break the quantity in gallons purchased down by month (to reflect seasonal demand/change)

A. Quantities are based on annual estimates that will vary month to month

(SIGNED): _____ (DATE): _____

(COMPANY): _____

Please sign one (1) copy of this page and return it with your proposal, or separately and clearly labelled if your proposal has already been submitted, to the Purchasing Department (email: aberkowitz@chattanooga.gov; or fax to 423-643-7244 Attn: A Berkowitz; or mail to Purchasing Dept., Attn: A Berkowitz, 101 E. 11th Street, Suite G-13, Chattanooga, TN 37402.

Retain a copy for your file.