

ADDENDUM NO. IV

BID NUMBER: 305960

BID TITLE: Liquid Calcium Nitrate

DEPARTMENT: Waste Resources Division, Public Works

DATE OF ADDENDUM: August 19, 2020

BID DUE DATE: August 26, 2020

BID DUE TIME: 2:00 p.m., e.s.t.

REASON: ANSWERS TO QUESTIONS

In order to maintain the bid opening date, we can no longer receive questions after this Addendum.

Q. How many calcium nitrate feed sites are there?

A. Currently there are ten sites we feed calcium nitrate at on Pump Stations. There is one site in the plant we feed Bioxide 71 at.

Q. Is this bid for calcium nitrate only or does it include Bioxide 71 plus as well? There was an addendum that mentioned this is for calcium nitrate only, but Bioxide 71 plus is mentioned in the specs.

A. We would be fine with someone bidding just the calcium nitrate and not the Bioxide Plus or Equal.

Q. There is mention of flow pacing based on temp control and influent flow to be supplied by the chemical supplier in the specs. Is this for the calcium nitrate feed sites or the Bioxide 71 plus feed sites?

A. This is used for Calcium Nitrate at three pump stations. Ringgold, Spring Creek and South Chickamauga.

Q. We would like to request the bid be postponed to a later date to allow time for proper site visit.

A. This bid will not be extended again.

(SIGNED): _____ (DATE): _____

(COMPANY): _____

Please sign one (1) copy of this page and return it with your proposal, or separately and clearly labelled if your proposal has already been submitted, to the Purchasing Department (email: aberkowitz@chattanooga.gov; or fax to 423-643-7244 Attn: A Berkowitz; or mail to Purchasing Dept., Attn: A Berkowitz, 101 E. 11th Street, Suite G-13, Chattanooga, TN 37402.

Retain a copy for your file.