

	<h1>City of Wilson, NC.</h1> <h2>Addendum 2</h2>
<p><u>Please send inquiries and questions about this RFP to:</u></p>	<p>RFP: 2023-32 – Demolition Services – 1673 Parkwood Boulevard</p>
<p>Ricky Wilson</p>	<p>RFP Due Date: (extended to: 07/26/2023 @ 2:00 pm)</p>
<p>Purchasing Manager rvwilson@wilsonnc.org</p>	<p>Contract Type: Demolition Services</p>

Failure to acknowledge and return this addendum may subject your bid to be rejected based on the below information.

Vendor: _____

Question 1: How far does the demo go away from the buildings? It is requested that all buildings and connected awnings, concrete sidewalks, and curbs be demolished.

Question 2: Will the contractor be responsible for getting the utilities disconnected such as cut & capping? This will be handled through the City of Wilson and with the awarded contractor, but the City will be providing this before the actual demo work begins.

Question 3: Will the slab and footers be part of this demolition? Yes, please refer to Attachment D, Demolition and Abatement Provisions in RFP document.

Question 4: Is there a preferred place to dispose of demolition material? The disposal is addressed in Attachment D of the RFP specifically (Disposal and Final Steps)

Question 5: Is there a fire hydrant for accessing water during demolition? A fire hydrant will be located and provided for the awarded contractor.

Question 6: Is this one contract or will it be split? This is for one contract and this demolition is not intended to be split. The city will award based off of Lowest Responsive Responsible Bidder.

This contract is for both abatement and demolition at the old bank building and demolition only at the old Kroger building*

Question 7: Can we get a picture of the roof of the old Kroger building? **Yes, see below and an additional attachment will be provided.**

