



**PURCHASING DIVISION**

901 Broadway, N.E. • Knoxville, TN 37917-6699  
 865.403.1133 • Fax 865.594.8858  
 800.848.0298 (Tennessee Relay Center)  
 Email: [purchasing@kcdc.org](mailto:purchasing@kcdc.org)  
<http://www.kcdc.org/en/DoingBusiness.aspx>

**Addendum**

<b>SOLICITATION NAME</b>	Exterior Door Replacement Services at Lonsdale Homes C14028	<b>ADDENDUM NUMBER</b>	2	<b>DATE</b>	07-10-14
--------------------------	---	------------------------	---	-------------	----------

KCDC is providing this addendum to answer questions that have been raised about this solicitation. To aid in readability, the questions are in black and the answers are in **bold** and the answers follow immediately below.

Q1	Is it a typo on Addendum 1 where it says no metal frames?
	<b>Metal frames are to be used with the interior wood door casing as indicated in the specification. Some vendors asked if they could use a metal insert frame with metal trim on the interior-that is not acceptable.</b>