

ADDENDUM NO. II

DATE: December 9, 2016
TO: All Bidders
FROM: Janice McClelland, Assistant Purchasing Agent
SUBJECT: Addendum No. 2 – Battery Backup Systems
BIDS TO BE OPENED: December 20, 2016, at 11:00:00 a.m.

This addendum becomes a part of the Contract Documents and modifies the original specifications as noted.

QUESTIONS SUBMITTED TO THE OFFICE OF THE PURCHASING AGENT

Q. What type of environment will the UPS be installed into? (office, idf closet, outdoors, etc.)

A. These will be used in the traffic signal control cabinets and must follow the NEMA Standards.

Q. What do you plan on plugging into the UPS? (routers, switches, servers, appliances, computers, etc.)

A. This will be responsible for maintain the entire traffic signal operation for the four hour duration specified.

Q. Will the required 1000 watt load scale up as the customer adds more equipment to the site? How much scalability is required?

A. No. The wattage will not be scaled up. None.

Q. Do you plan to monitor and manage the UPS? If so will the 2 new UPS's be additional nodes part of a larger managed hardware package?

Yes, but this will be managed by our Traffic Operations Central Software.

END OF ADDENDUM NO. II