



Terry McKee, IT & Procurement Director

901 N. Broadway • Knoxville, TN 37917-6699
 865.403.1133 • Fax 865.594.8858
 purchasinginfo@kcdc.org
 www.kcdc.org

Addendum

SOLICITATION NAME	Interior Water Line Replacement Services at Autumn Landing Q1807 and Nature's Cove Q1810 Round 2	ADDENDUM NUMBER	1	DATE	11-19-17
--------------------------	---	------------------------	---	-------------	----------

This addendum answers questions raised about this solicitation. To aid in readability, the questions are in black, the answers are in **bolded blue**, and the answers follow immediately below.

Q1	Does the vendor insulate the pipe?	Only that pipe that is on the exterior wall.
Q2	How long can the water be off?	Since the units are occupied, water must be turned back on by 4:00 p.m.
Q3	What kind of access panel is required?	Plastic
Q4	Do we remove the kitchen cabinets or pipe it on the side?	Run the pipe on the side of the cabinet.
Q5	Are we replacing the mixing valves?	No
Q6	How many pieces are the tub/shower units?	At Autumn Landing they are one piece. At Nature's Cove they are three piece.
Q7	Are there pressure-reducing valves?	No.
Q8	What type of copper are the existing pipes?	Copper M.
Q9	Are the ceilings popcorn style?	Yes and they must be restored as such.

