

ADDENDUM NUMBER THREE
Focused SSES and Rehabilitation South
Chickamauga Creek 1 – Phase 2
CONTRACT NUMBER W-17-021-201
FOR THE CITY OF CHATTANOOGA, TENNESSEE

Contract Documents and Drawings:

The following changes shall be incorporated into the requirements for the above referenced Project:

1. Contractor shall not be permitted to impact the wetlands shown on the Drawings (Sheet 7 of 14) located along the sewer between Stations 37+00 and Station 40+00. No equipment or vehicles will be permitted in this area and the Contractor shall assume there will be no access to manhole S127C020. Contractor shall extend CIPP liner through manhole S127C020 from an adjacent manhole. Installed CIPP liner shall remain closed (i.e. not trimmed and sealed) in manhole S127C020. Rehabilitation and replacement of watertight frame and cover at manhole S127C020 shall be completed without impact or entrance within wetlands area shown on the Drawings. Notify Owner/Engineer if work at manhole S127C020 cannot be completed without disturbing the wetlands area.
2. CORRECTION: Sheet 8 of 14. Pipe is to be replaced from manhole S127D022 to manhole S127E011.
3. CORRECTION: Sheet 9 of 14. A CIPP liner is not to be installed in pipe between manholes S127D022 to S127E011.

Bidder shall indicate receipt of all addenda on Bid Form.

July 3, 2019

/s/Justin C. Holland, Administrator
City Of Chattanooga
Department of Public Works