

Addendum Four
Focused SSES and Rehabilitation South
Chickamauga Creek 1 – Phase 2
CONTRACT NUMBER W-17-021-201
Request for Bidder Information

The deadline for submission of bids has been extended to **2:00 p.m.**, local time, on **August 1, 2019**. Sealed bids are to be submitted to City of Chattanooga at City Hall, Purchasing Department, Suite G13, 101 East 11th Street, Chattanooga, TN 37402.

- Q&A:

1. Reference Drawing 11 of 14 Detail 1 Temporary Access Path/Timber Mats. Can Composite Mats be used in lieu of Timber Mats? If so, can the mulch be deleted if Composite Mats are used?

The use of Composite Mats, such as Dura-Base Composite Mats manufactured by Newpark Resources, Inc. (or approved equal), may be used in lieu of Timber Mats.

If Composite Mats are used they shall be installed in accordance with manufacturer's recommendations, including the use of locking pins to secure the mats together, as well as plugs in unused locking hole locations to prevent piping of underlayment materials onto the mat surface.

No vehicles will be permitted to drive within the construction limits shown on the Drawings unless they are located on a timber mat or composite mat. This includes during installation and removal of mats.

A mulch base underlayment will not be required under Composite Mats.

July 17, 2019

/s/ Justin C. Holland, Administrator
City of Chattanooga
Department of Public Works