

ADDENDUM NUMBER TWO
Focused SSES and Rehabilitation South
Chickamauga Creek 1 – Phase 2
CONTRACT NUMBER W-17-021-201
FOR THE CITY OF CHATTANOOGA, TENNESSEE

Questions and Answers:

- 1. Will the Owner/Engineer please provide the budget for this project?
 - *No.*

- 2. Will the Owner/Engineer please provide any previous itemized bid tabulations for projects of similar scope?
 - *No.*

- 3. Will the Owner/Engineer please provide a copy of the current plan holders list?
 - *Copy of the plan holders list can be requested from 8:00 am to 4:30 pm, Monday through Friday, at the office of the City of Chattanooga Purchasing Department, 101 East 11th Street, Suite G13, Chattanooga, TN 37402.*

- 4. Will the Owner/Engineer please provide the anticipated NTP date for this project?
 - *The anticipated Notice to Proceed (NTP) date for this project is **November 22, 2019**. However, Owner-initiated permit reviews by regulatory agencies are ongoing. NTP will not be issued to Contractor until approval of all owner-initiated permits.*

- 5. Will the Owner/Engineer please confirm if there are any prevailing wage requirements for this job?
 - *The minimum wages to be paid on this project are governed by the Davis-Bacon Act. Refer to Specification 00 73 00 (Supplemental Conditions) for additional information regarding prevailing wage rate requirements.*

- 6. Will the Owner/Engineer please clarify whether air inversion and steam curing is acceptable? It is beneficial/cost effective to the Owner especially for lining small diameter scope of works like this project.
 - *The preferred method of installation and cure for CIPP is inversion using hydrostatic head (water column) pressure and curing with heated, circular water. The use of air inversion/steam cure will only be considered on a case-by-case basis only. Contractor should not assume in preparation of their bid that the use of pressurized air/steam will be approved by the Owner/Engineer.*

- 7. As we walk the job we have observed that the access through industrial establishments is physically blocked, locked up and our walk cannot be completed. Will the Owner/Engineer please clarify whether it is the Contractor's responsibility to sort out this matter or any assistance from the Owner/Engineer can be provided?
- *Contractor is responsible for coordinating their site access with affected property owners.*
- 8. With reference to our previous question #7, Will the Owner/Engineer please provide 1 week extension to the bid due date because of job walk - site access issues, forthcoming holidays (4th of July)?
- *No extension will be provided.*

July 2, 2019

/s/Justin C. Holland, Administrator
City Of Chattanooga
Department of Public Works