



**Spartanburg County School District Seven  
Cypress Creek Storm Drain Project  
Addendum No. 2  
June 25, 2020**

This Addendum #2 is intended to address questions or clarify District requirements on the above referenced project. This and all Amendments (Addenda) should be acknowledged on page 2 of the Invitation for Bid (IFB) OR should be acknowledged by returning this form along with bid or proposal.

**Bids are due Tuesday, June 30, 2020, at 2:00 PM (EST). Sealed offers shall be submitted to Spartanburg County School District Seven Procurement Office (610 Dupre Drive, Spartanburg, SC 29307).**

- Item 1. A construction duration was discussed at the pre-bid; however, District Seven has decided to coordinate the construction schedule with the successful bidder. A set duration time is not part of the bid documents. The District does not plan on liquidated damages for this project.
- Item 2. A revised Bid Tab is included in this addendum. Unit prices for additional excavations (undercut beyond 8" below the pipe) and additional stone bedding associated with the undercut. All additional excavation shall be determined and confirmed by the geotechnical engineer, a third party inspector provided by the Owner.
- Item 3. The allowance included in the base bid (\$30,000 for landscaping) shall not be eligible for contractor mark-up.

(Item 4 on next page)

Addendum #2 continued:

- Item 4. In response to a question regarding the building located on the Cash property... This was discussed at the pre-bid. The current plan is to bypass the building, staying within the existing easement. The Contractor shall coordinate any field adjustments with the Engineer. The building shall remain in place.

**Addendum #2**

**Authorized Signature** \_\_\_\_\_

**Company** \_\_\_\_\_

**Date** \_\_\_\_\_