



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: August 26, 2020
TO: Prospective Respondents
FROM: Amy Lucey, Contracts Administrator
SUBJECT: Addendum #4 to Invitation for Bids # 35891, S96D Rehabilitation

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

- Q1: Should bid tab item #8 be SF in lieu of CF?
A1: This item is for isolated patching: CF is correct.
- Q2: What is the weight of the existing gate?
A2: The weight of the existing gate is \pm 11,200 lbs.
- Q3: What is the rating of the existing service bridge?
A3: The bridge was designed for dead load plus H20-44 truck live load.
- Q4: What is the width and weight capacity of the service bridge that crosses the structure?
A4: The bridge is 12'-0" wide between the curbs and has been designed for dead load plus H20-44 truck live load.
- Q5: The detail for the sheet steel pile cap piece is missing a length dimension; could the district provide this for bidding purposes?
A5: The plate size for the S8/4 Cap Plate Detail is 3/8"x6"x8".

Attachments:
Additional As- Built Drawings – separate cover

NOTE: The Bid Opening **remains** 2:00 p.m., **Tuesday, September 8, 2020**

Please acknowledge receipt of this Addendum on the **BID FORM** provided in the bid package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.