

ADDENDUM #2

TO

SPECIFICATION AND CONTRACT DOCUMENTS

March 12, 2019

TO: ALL PLAN HOLDERS
FOR: ITB-012-2019
Extension to Existing Pole Barn

The purpose of addendum #2 is to change the scope of work in the bid and to allow extra days for questions since the due date was extended to March 21, 2019 in the previous addendum 1.

DEADLINE FOR QUESTIONS HAS BEEN EXTENDED TO MARCH 14, 2019 AT 4:00 PM LOCAL TIME.

Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.

1. The scope of work states you want to extend the length of the building 60' by making two 30' bays. The current bay spacing is 20' bays, by changing the bay spacing to 30' bays, the purlins and eave struts would not match up with the existing building which would create a problem to tie in the extension building. How would you like to proceed?

Answer: Please change the scope to three (3) 20 foot bays.

No. 1 Dated _____

Signature: _____

No. 2 Dated _____

Signature: _____

THIS FORM MUST BE INCLUDED WITH PROPOSAL