



Addendum No. 3
Santa Cruz Valley Unified School District
Invitation for Bid (IFB) 21-04
Roofing Repair / Replacements at 4 Campuses

Santa Cruz Valley Unified School District
Roof Replacements

Calabasas School: SFB 120235130-9999-012 BRG
Coatimundi Middle School: SFB 120235110-9999-014 BRG
Mountain View Elementary School: SFB 120235120-9999-013 BRG
Rio Rico High School: SFB 120235200-9999-011 BRG

ADDENDUM NO. 3
December 30, 2020

TO ALL BIDDERS:

The following items modify or clarify the contract documents for the above projects. In the event of conflict, all information herein shall take precedence over the drawings and specifications.

All Bidders are reminded to acknowledge receipt of Addenda in the space provided on the Bid Form.

GENERAL COMMENTS / CLARIFICATIONS:

1. All Campuses: Addendum No. 2 Item 1 is deleted.
2. Coatimundi Middle School and Rio Rico High School: Specifications Section 075216 Paragraph 3.5 Installation of Cover Boards, Subparagraph A.4, revise as follows:
 4. Adhere cover board to substrate using adhesive according to SPRI's Directory of Roof Assemblies listed roof assembly requirements for specified Wind Uplift Load Capacity and FM Global Property Loss Prevention Data Sheet 1-29, as follows:
 - a. Set cover board in a solid mopping of hot roofing asphalt, applied within plus or minus 25 deg F of equiviscous temperature.



REGISTRATION EXPIRATION DATE: 3/31/2023

END OF ADDENDUM NO. 3 FOR IFB 21-04
