

Questions Submitted Via Email

1. Is there any data on the water table in the area? *No data is available.*
2. Can we pull casing under the road ways instead of cutting through them? *Using steel casings installed by jack and bore in lieu of open cutting the roads is acceptable if it is constructible in accordance with SCDOT and Dorchester County requirements. The bidder would need to determine if it will work.*
3. Are driveways to be restored only within the trench cut or are they replaced road to edge of the right of way? *The driveways are to be restored to the extent they are damaged by the construction.*
4. The Stratton Capers Instructions to Bidders indicates that a bid bond form included in the documents is to be used, however we can't find one included. Is there a form to use or is the standard issue from our bonding company sufficient? *Standard issue from your bonding company is sufficient.*