



THE CITY OF DAYTONA BEACH
OFFICE OF THE PURCHASING AGENT

Post Office Box 2451
Daytona Beach, Florida 32115-2451

Phone (386) 671-8080
Fax (386) 671-8085

ADDENDUM NO. 2

DATE: May 24, 2019
PROJECT: HYDROGEN PEROXIDE
19450

OPENING DATE: June 4, 2019

This addendum is hereby incorporated into the Bid Documents for the project referenced above. The following items are clarifications, corrections, additions, deletions and/or revisions to and shall take precedence over the original documents. Additions are indicated by underlining, deletions are indicated by ~~strikethrough~~.

1. Answers to Bidders' written questions:

Q1: What is the concentration and grade of the H₂O₂?

A1: Per page 28, the concentration of H₂O₂ is 30%. Grade NSF for drinking water.

Q2: Will the City consider offers for supply of H₂O₂ in bulk if the vendor supply storage tanks and feed equipment as needed?

A2: The City will accept bulk if Contractor delivers 3000-4420 pounds per delivery. The City has a 550 gallon tank, and own our own feed equipment.

2. Page 28, paragraph 1 under delivery:

The liquid Hydrogen Peroxide shall be delivered in 3000 pound totes or in bulk delivering 3000-4420 pounds per delivery to Ralph Brennan Water Treatment Plant, 3651 LPGA Blvd, Daytona Beach, FL 32124. Delivery will require offloading of totes by delivery driver. Annual estimated quantity of 129,000 pounds.

3. All other terms and conditions remain the same.

The Bidder shall acknowledge receipt of this addendum on the Bid Proposal Form.

The City of Daytona Beach

Kirk Zimmerman, CPPB
Buyer