



CITY OF CALLAWAY
6601 East Highway 22
Callaway, FL 32404

ADDENDUM #1

DATE: January 8, 2018

PROJECT NAME: BID NO.: PW2017-16 - LIFT STATION CA-24 IMPROVEMENTS

This addendum is being released to address questions asked regarding the project.

- 1. Specification section 15700 paragraph 2.06 states that a new control panel is to be supplied for this project, however there is no other information available regarding the controls. Can you confirm that a new panel is required for this project? If not and the existing panel is to be re-used, can you advise what voltage and HP the existing panel is setup for?

The existing panel will be used. CA-24 has 25 HP pumps and supply voltage is 230 VAC.

[Handwritten signature of Janice L. Peters]
Janice L. Peters, MMC, City Clerk

Receipt of Addendum #1 must be acknowledged and included with the bid packet submission.

Printed Name _____ Company Name _____ Date _____

Signature _____