

Bid #2208, Anderson County Park RV Expansion

Question & Answer #2

1. Will contractor be allowed to abandon the existing waterlines that go through the site in place once the new waterlines are installed?

Answer: Yes the contractors can abandon the existing water lines in place. They will need to be capped at the point of the disconnection.