

ADDENDUM NO. 8

March 16, 2022

THE CITY OF SPARTANBURG, SOUTH CAROLINA
SPARTANBURG FIRE STATION ONE
450 Wofford Street, Spartanburg, SC 29301
Architect's Project No. 1599

Each Contractor shall be responsible for each item of the Addendum as stated herein and shall coordinate each item with his particular portion of work. Each Contractor shall coordinate with all other Contractors for satisfactory completion of each item of the addendum and the total project. The Prime Contractor shall be responsible for seeing that his subcontractors/material suppliers are properly apprised of the contents of this Clarification. The following clarifications, amendments, additions, deletions, revisions, and/or modification are hereby made a part of the Contract Documents, and change the original documents only in the manner and to the extent stated herein.

CIVIL DRAWINGS:

- C7.0** Water valve moved to be adjacent to the existing water main. Service line to main connection note updated to show that the existing main is cast iron. Water main call out updated to show that the existing main is cast iron.

ARCHITECTURAL DRAWINGS:

- 6.11** Remove faced sound attenuation insulation in all new Toilet & Shower stall ceilings.
6.12 Added gypsum board bulkhead in the ceiling of Training Room-128 to conceal the W21 steel beams above.
7.10 Finish tag for the fire pole platform is noted and updated CLG-3 & 5 ceiling specs descriptions.

PLUMBING DRAWINGS:

- 8.10** Rated wall fire rating legend added.
8.11 Rated wall fire rating legend added.
8.12 Rated wall fire rating legend added.
8.13 Rated wall fire rating legend added.

FIRE PROTECTION DRAWINGS:

- 8.60** Fire review clarification comments added.
8.70 Rated wall fire rating legend added. Updated ceiling classifications.

MECHANICAL DRAWINGS:

- 9.11** Mechanical legend updated and Fire damper added at Vestibule-110.
9.12 Mechanical legend updated and Plymovent system note added.
9.13 Mechanical legend updated.
9.14 Mechanical legend updated.

ELECTRICAL DRAWINGS:

- 10.02** Fire alarm riser diagram level notation revised.
10.11 Rated wall fire rating legend added.
10.12 Rated wall fire rating legend added.

- 10.13** Rated wall fire rating legend added.
- 10.14** Rated wall fire rating legend added. Note 12 added and noted on plans.
- 10.21** Rated wall fire rating legend added.
- 10.22** Rated wall fire rating legend added.
- 10.23** Rated wall fire rating legend added. Light fixture device added in elevator lobby.

END OF ADDENDUM #8