

ADDENDUM NO. 3
HAMILTON ROAD WATER AND SEWER RELOCATIONS
CITY OF LAGRANGE
LAGRANGE, GEORGIA

ADDITIONAL INFORMATION DOCUMENTS

The following document:

- Questions and Responses

is being provided with this addendum for informational purposes only. The document listed above is not, and will not, be considered as part of the Contract Documents.

Bidder Must Acknowledge Receipt of this Addendum on Bid Form

January 31, 2023
Barge Design Solutions, Inc.
1201 Front Ave, Suite F
Columbus, Georgia 31901
706-321-4583

QUESTIONS AND RESPONSES

HAMILTON ROAD WATER AND SEWER RELOCATIONS

**CITY OF LAGRANGE
LAGRANGE, GEORGIA**

QUESTIONS:

Question: There is 100s of feet of gas main within 10' of the waterline and casing. Will the owner be providing the polywrap for the ductile? Can you give us some sort of idea about how much coated casing we need?

Response: All the gas is being relocated and will be plastic, so there won't be any need for polywrap.

Barge Design Solutions, Inc.
1201 Front Ave, Suite F
Columbus, Georgia 31901
706-321-4590