



ADDENDUM No.2

2017 CDBG (Community Development Block Grant) Sidewalk Install/Repair

Contract Number: T-17-006

Chattanooga Department of Transportation

Question /Comment 1: How many handicap curb ramps are there for this project?
Can you tell me the square footage of detectable warning surface needed?

Answer: There will be approximately 23 ramps - 4
radial, one combination. There will be approximately 280 sq. ft.