

Georgetown County, South Carolina

129 Screven Street, Suite 239 Post Office Drawer 421270 Georgetown, SC 29442-4200 (843) 545-3083 • Fax (843) 545-3500 E-Mail • <u>purch@gtcounty.org</u> Website • <u>http://www.gtcounty.org</u>

ADDENDUM #4 TO BID #19-075

BID NUMBER: 19-075 ISSUE DATE: Monday, November 4, 2019

(REVISED) OPENING DATE & TIME: <u>Tuesday</u>, November 12, 2019 at 2:30 PM (ET)

Bid Opening Location: Georgetown County Courthouse, Suite #239, (Purchasing Conference Room)

Pre-Bid Site Inspections: [Voluntary-On Own]

PROCUREMENT FOR: <u>Purchase & Installation of Emergency Standby Generators at</u> <u>Various County Facilities</u>

This addendum will amend <u>Bid #19-075, Purchase & Installation of Emergency Standby</u> <u>Generators at Various County Facilities</u> originally issued on Wednesday, October 9, 2019. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: <u>www.gtcounty.org</u>, select "Bid Opportunities" from the Quick Links section and "View Current Bid Solicitations."

REVISION:

Due to some confusion regarding the NFPA 110 specifications, it has been brought to our attention that not all models listed in the bid document are NFPA 110 capable. Therefore, for bidding purposes and fair comparison, please quote the models or equivalent as indicated in the bid document. Per the County Fire Chief, NFPA 110 requirements will be waived as long as it meets the Georgetown County adopted Electrical Codes. No further questions, clarifications, or addendums will be issued. If it is later on discovered that this is a grant requirement and models need to be adjusted, we will do so with the awarded bidder, if needed.

2nd BID OPENING CHANGE:

Due to the late issuance of Addendum #4, the bid opening date will be pushed back once again to allow time for bids to be received from vendors. No further questions will be received. The new timeline is listed below. Please keep in mind, County offices will be closed on Monday, November 11, 2019. Therefore, if mailing your sealed bid, please ensure it arrives by the new deadline listed below.

Item	Date	Time	Location*
Advertised Date of Issue:	Wed., October 9, 2019	n/a	n/a
Pre-Bid Conference/Site	Voluntary-On Own	n/a	n/a
Inspection:			
Deadline for Questions:	Wed., October 23,	2:30PM ET	Suite 239
	2019		
(REVISED) Bids Must be	Tuesday, November	2:30PM ET	Suite 239
Received on/or Before:	12, 2019		
(REVISED) Public Bid Opening	Tuesday, November	2:30PM ET	Suite 239
& Tabulation:	12, 2019		

[THE REMAINDER OF THIS PAGE IS INTENTIONALLY LEFT BLANK]



ADDENDUM ACKNOWLEDGEMENT

Bid #19-075 <u>Purchase & Installation of Emergency Standby Generators at</u> <u>Various County Facilities</u> Mandatory Submittal Form

To be returned with the final proposal submission to Georgetown County.

COMPANY NAME:

0	Addendum #1 Received Date:	Initialed By:
0	Addendum #2 Received Date:	Initialed By:
0	Addendum #3 Received Date:	Initialed By:
0	Addendum #4 Received Date:	Initialed By:
	Addendum #5 Received Date:	Initialed By:
	Addendum #6 Received Date:	Initialed By:

If your Bid submission has already been mailed, acknowledgment may be provided by faxing this form to (843)545-3500, or attaching a digital scan and sending by e-mail.

[THE REMAINDER OF THIS PAGE IS INTENTIONALLY LEFT BLANK]