



**CITY OF CALLAWAY
POLE BARN PROJECT
BID NO.: PW2018-01**

ADDENDUM #1

Date Issued: January 23, 2018

This addendum is being released to clarify questions asked of the bid and to change the specifications of Job #4 as follows:

1. **Job #2:** Could an alternate bid of a 12'6" aluminum structure be submitted for this job to allow for taller trucks to pull underneath it?
A. YES

2. **Job #4:** The 6"x6" posts are hereby changed to 8"x8" posts to prevent bending and warping.



Janice L. Peters, City Clerk

This Addendum must be acknowledged and included with the bid packet submission.

Signature

Company Name

Date