

## ADDENDUM NO. 2

**DATE:** August 18, 2021

**TO:** All Bidders

**FROM:** Taylor Childress, Procurement Specialist

**SUBJECT:** Addendum No. 2 – Underground Storage Tank Repairs

**SUBMISSIONS DUE:** August 24, 2021 2:30 PM (Eastern Time)

This addendum is being published to provide clarification regarding the above referenced request for quotes. This addendum becomes a part of the contract document and modifies the original specification as follows:

Items for Clarification:

**Question:** Are there any special licenses required for this project?

**Answer:** The awarded contractor must be certified by the manufacturer for proper installation of the equipment. The awarded contractor must also complete all hydrostatic spill bucket testing and flapper valve functionality testing for the installed spill buckets and drop tubes in compliance with 40 CFR 280.35. The awarded contractor shall also provide successful tests documentation to the below listed agencies ensuring compliance with 40 CFR 280.20(c)(i), 40 CFR 280.20(c)(ii)(A), and TN UST Regulatory Requirement 0400-18-01-.02(1)(b).

1. Tennessee Department of Environment and Conservation – Underground Storage Tank Division (Knoxville Office)
2. UST & Data Management Section, Environmental Protection Agency – Region IV (Atlanta)
3. Copy furnished to Knoxville Area Transit, Maintenance Director

**END OF ADDENDUM NO. 2**