



Spartanburg School District 2
RFB Cooling Tower Replacement: Boiling Springs Elementary

ADDENDUM 1

April 12, 2018

This Addendum #1 is being released to address questions that were discussed during the pre-bid meeting.

- 1) A stainless steel cold water basin is required. Your total bid price shall include this.
- 2) The old unit must be removed, but the gearbox and fan will be given back to Spartanburg School District Two.