



ADDENDUM NO. 7

Issue Date: February 18, 2021

Project Name: 66th Ave Widening (49th St to 69th St) – IRC-1505

Bid Number: 2021018

Bid Opening Date: **February 24, 2021**

This addendum is being released to provide clarification, corrections, or change of the Bid Documents. The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

Questions and Answers

1. What does the County define as abnormal weather conditions, in order to compensate Contract Time?
General contract time extensions for weather related delays will follow FDOT Standard Specifications for Road and Bridge Construction, January 2015, Section 8-7.3.2.
2. In addendum #3, in the pre-bid discussion notes Brian Good states "Class IV RCP shall be used" does that pertain to Phase 1B only, there is no referenced to that in Arcadis's plans for Phase 1A? When will the updated plans be issued to show the added 60" RCP, 72" RCP, and additional Rip Rap Rubble in Phase 1A?
"Class IV RCP" shall apply to the project limits of phase 1A and 1B. Updated plans will be issued with the "Released for Construction" Contract Plans.
3. Please clarify if the last two joints of the 48" x 76", 60", 66", and 72" RCP runs that end with the Rip Rap Rubble end treatments will require concrete collars as the show in the Phase 1B Kimley Horn plans?
The above referred pipes in the phase 1 A section will end with a rip rap rubble end treatment and the quantities for rip rap have been updated with Addendum 6. A concrete collar is not added to the end treatment.
4. Items 400-148 for Phase B itemized bid schedule show a quantity of 2 for both the 61st and 65th street bridges, but the quantity is being calculated by 1.7 for each item.
The correct quantity for both bridges item no. 400-148 is 1.7 CF. If you are using the excel bid sheet, it will calculate with a quantity of 1.7 CF and no changes are required. If you are using the pdf sheet (Itemized Bid Schedule, page 00310-17), please change the quantity for item 400-148 and 400-148A from 2 CF to 1.7 CF (two locations).